LOT 31 CLARK STREET STORMWATER MANAGEMENT OPERATIONS AND MAINTENANCE REPORT

TOWN OF THE BLUE MOUNTAINS
PROJECT No. 2021-185



Table of Contents

ntroduction	1
SWM Facility and Infrastructure	1
Vegetated Swale	2
Storm Sewer Network	3
Oil Grit Separators	3
Flood Bypass Culvert	3
Erosion and Sediment Control Measures	3
SWMF & Infrastructure Inspection and Maintenance Program	3
Frequency of Inspection	3
Inspection Checklist	4
Maintenance Tasks	4
Grass Cutting	4
Weed Control	4
Plantings	5
Trash/Debris Removal	5
Sediment Removal	5
Cleanout Frequency	5
Method of Sediment Removal	e
Sediment Disposal	6
Outlet Control Structure Cleanout	6
Winter Operations	7
Unscheduled/Emergency Maintenance	7
Conclusions	7

Appendices

Appendix A – Erosion and Sediment Control Drawings

Appendix B – SWM & LID Infrastructure Drawings

Appendix C – Inspection Checklist

Appendix D – Landscape Drawings

Appendix E – Sediment Removal Calculations

Appendix F – OGS Information

Introduction

CAPES Engineering Ltd. has been retained by Pantone Capital Inc. to prepare a functional servicing and stormwater management report in support of a Site Plan Agreement for the 3.74 ha site located at the intersection of Highway 26, Grey Rd 2 and Clark Street in the Town of The Blue Mountains.

This Operations and Maintenance Manual has been prepared for the Owner to provide a comprehensive maintenance program for the stormwater management pond and other stormwater features proposed for the site.

The stormwater management facility (SWMF) is located in the central part of the site, between the self-storage buildings in the south and the industrial use building in the north. The SWMF has been designed as a dry pond with oil grit separators upstream of the facility to provide the necessary quality and quantity control for the site.

Additional SWM controls are proposed as follows:

- Vegetated swales
- Storm sewer system
- Oil Grit Separators
- Flood bypass culvert

Full details of the SWM design are described in the Stormwater Management Report prepared by CAPES Engineering Ltd. dated December 13, 2023.

This report outlines maintenance responsibilities, inspection, and procedures in accordance with the current Ministry of the Environment (MECP) Stormwater Management Planning and Design Manual (2003) and the Town of the Blue Mountains Engineering Standards (2023).

An Environmental Compliance Approval (ECA) is required from the MECP for the on-site SWM controls as the site is zoned industrial. Once the Environmental Compliance Approval is issued by the MECP they should become a part of this document.

SWM Facility and Infrastructure

The dry pond SWMF will be privately owned and maintained by the owner of the site and is intended to provide:

- An enhanced level of quality control as per the MECP Guidelines
- To assist in the quantity control and conveyance of post development runoff for all storms up to and
 including the 100-year storm. Conveyance only will be provided for the Regional event through the
 SWM facility to the Hwy 26 ditch system.

The SWM pond parameters and operating characteristics are described in the Stormwater Management Report prepared by CAPES Engineering Ltd. A control manhole has been provided for the SWMF which allows inspection and maintenance without entering the pond itself. The control manhole is located within the berm on the east side of the SWMF and can be accessed via the 4.0 m wide maintenance road. The SWMF bottom is set at elevation 184.00 while the top of berm elevation is set at 185.90.

Stormwater runoff is directed into the SWMF via pipes from the north and south and from a vegetated swale from the SW. The flow discharges through two OGS units for the piped flow while flow from the swale discharges directly to the facility.

The SWMF is equipped with a 0.5 m deep micropool area which is intended to collect additional sediment prior to discharging flow from the facility. A 525 mm dia. pipe connects the micropool to the outlet control structure. The control structure consists of a manhole with an internal concrete midwall with a 75 mm dia. circular orifice to control frequent storm events and a trapezoidal weir set above that to control less frequent storm events.

A 300 mm dia. pipe connects the outlet structure to the discharge point set just outside of the MTO 24 m wide setback from the highway. Flow discharges at this point and travels within the existing watercourse/drainage channel to the Hwy. 26 ditch system.

The maximum water surface elevation in the SWMF occurs during the 100 year storm event with a modelled water level of 185.50. The water surface elevation is expected to reach an elevation of 184.42 during the 25 mm storm event and 185.18 during the 5 year storm event. The Regional (Timmins) storm only reaches an elevation of 185.22.

An emergency overflow spillway has been provided in the SWMF for extreme flow events or in the event the outlet structure becomes blocked. The opening of the overflow spillway is set at 185.55 and as such ponded water should not normally discharge over the spillway.

Vegetated Swale

There is a trapezoidal swale with a 0.25 m wide bottom and 3:1 side slopes with a required 0.40 m minimum depth located between the main access road and the self storage building area. The swale drains north to the SWMF and is to be grassed. The grass within the swale can either be mowed or left to grow long as desired by the Owner.

Any trash or debris accumulated in the swale should be removed yearly and sediment should be removed when it exceeds 0.05 m.

Storm Sewer Network

There is a subsurface storm sewer network complete with catchbasins within the asphalt area of both the north and south sites which are intended to collect runoff from storms up to and including the 100 year storm event.

The manhole lids should be lifted in the Spring of each year to check for the amount of accumulated sediment and/or any trash or debris. When the sumps on each storm structure reaches 50% of the capacity the sumps should be cleaned out using a vacuum truck.

Oil Grit Separators

The storm sewer network connects to two Oil Grit Separators (OGS) (CDS Model PMSU2025-5-C and PMSU2015-4-C) located between the SWMF and the edge of the asphalt on both the north and south areas of the site. The OGS units are intended to clean the stormwater runoff prior to discharge to the dry SWMF.

Please refer to the manufacturer's user's manual included in **Appendix E** for the required maintenance activities and details, including frequency and method of filter cleaning/replacement.

Flood Bypass Culvert

There is a 2130 x 860 CSP open bottom arch culvert located in the NW part of the site which is intended to allow flood flows to bypass around the site to the Hwy. 26 ditch system. This culvert needs to be inspected twice per year to ensure that the openings are free of debris and clear. In particular we recommend that the openings of the culvert be cleared of any accumulated snow and ice prior to the yearly spring thaw to ensure the full capacity of the culvert is available.

Erosion and Sediment Control Measures

All maintenance activities during construction of the SWMF and development of the site will be the responsibility of the developer and shall be in accordance with the engineering drawings prepared by CAPES Engineering Ltd. Please refer to **Appendix A** for the ESC drawings.

SWMF & Infrastructure Inspection and Maintenance Program Frequency of Inspection

The dry pond will require careful monitoring, particularly in the initial years of operation to ensure it is functioning properly and erosion is not occurring. Inspections are an important part of this monitoring program. Regular visual inspections should be conducted:

- After every significant rainfall (> 10 mm) for the first two years of operation.
- Minimum of four visits per year after the first two years of operation (spring, summer, fall and winter).

The vegetated swale will also require regular inspection and maintenance by the Owner. Including removal of trash and debris and removal of accumulated sediment when it reaches 0.05 m deep.

The storm sewer system and associated storm manholes will need to be inspected by the Owner twice per year (Spring and Fall) as part of a regular storm manhole inspection program.

Please refer to **Appendix B** for the SWM related drawings for the site.

Inspection Checklist

An inspection checklist has been included in **Appendix C**. This checklist shall be completed following each site visit. The Town of Saugeen Shores may keep a record of the completed checklists.

Maintenance Tasks

Grass Cutting

Generally, it is recommended that grass-cutting be limited or eliminated around the SWMF since allowing grass to grow tends to enhance water quality and provide other benefits for wet facilities. Short grass around a stormwater facility provides an ideal habitat for nuisance species such as geese. Allowing the grass to grow is an effective means of discouraging geese.

Grass cutting is one maintenance activity which is solely undertaken to enhance the perceived aesthetics of the facility. The frequency of grass cutting depends on surrounding land uses, and local municipal bylaws. Therefore, grass cutting should be done as infrequently as possible, recognizing the aesthetic concerns of nearby residents.

Landscape plans have been prepared for the pond including small shrubs and water tolerant plants, these plants are not to be mowed unless specifically required on the landscape plans.

As a safety precaution, grass cutting should be done parallel to the shoreline with grass clippings being ejected upland to reduce the potential for organic loadings to the pond.

Should the Owner wish to cut the grass around the facility, the following practices should be considered:

- Minimize frequency of cutting.
- Do not cut grass up to edge of the facility (to maintain shading and nutrient uptake).
- Do not blow grass clippings into the facility (to minimize organic loading in basin).

Weed Control

Weeds are generally defined as any kind of vegetation which is unwanted in a particular area. In terms of the SWMF, weeds are generally invasive species which cannot provide the intended function of the planting strategy, or non-native species such as purple loosestrife, the spread of which is undesirable. Weed control may be required annually.

Weed control will be required in the SWMF until the landscaped vegetation has been established. Weed control will not be required beyond these initial requirements immediately following construction and is

not an anticipated or recommended practice for this facility. Weed control is not required for any other SWM controls on the site.

Weeding should be done by hand to prevent the destruction of surrounding vegetation. The use of herbicides and insecticides should be prohibited near the SWMF since they create water quality problems. The use of fertilizer should also be limited to minimize nutrient loadings to the downstream receiving waters.

Plantings

Any replacement plantings required for the SWMF due to disturbance or die-out are to be in accordance with the Landscape Plans (**Appendix D**). Native species should be utilized where possible for all plantings.

Trash/Debris Removal

Trash removal is an integral part of the SWMF maintenance. Generally, a "spring cleanup" is needed to remove trash from the SWMF. Trash removal is then performed as required based on observations during regular inspections.

Accumulated litter and debris within the SWMF can be removed by hand by the Municipality during the regular inspection periods.

The Owner should also remove litter and debris from the swale, culverts and storm sewer structures as part of their regular yard maintenance.

Sediment Removal

In order to maintain the removal efficiency of the SWMF, the accumulated sediment will need to be removed periodically. Any sediment build-up in the micropool, main cell and outlet structure will need to be removed to maintain pond volumes.

Sediment accumulation in storm sewer manholes within the asphalt area should be removed as part of a regular site maintenance program, but at a minimum should be removed when the sump reaches 50% full.

Cleanout Frequency

The accumulated sediments within the SWMF should be excavated once one half of the capacity of the main cell (0.20 m) is reached or every 10 years whichever comes first. A sediment removal frequency calculation is provided in **Appendix E**. As the calculations show a theoretical very long time period to the required sediment accumulation it is proposed the facility will be cleaned out every 10 years.

The storm manholes on the site should be cleaned out when the sumps have reached 50% full or once a year whichever comes first. Cleaning out the manholes is critical to ensuring the long-term performance of the perforated storm sewer and should ideally be completed in the early Spring.

Method of Sediment Removal

The following is a suggested method of sediment removal for the SWMF:

- Obtain samples of the accumulated sediment and test as per the requirements of the MECP Sediment Testing Guidelines
- 2. Pump out any water from the pond to the downstream side of the outlet control manhole concrete midwall. Use a silt bag at the end of the pumped effluent and place intake on a hard surface such as a patio stone.
- Excavate accumulated sediments using an excavator (equipped with long boom) from the pond. Excavated sediment shall be placed immediately in a truck for disposal to minimize disturbance of existing vegetation. During excavation, it will be very important to ensure that the geosynthetic clay liner located 1 m below the bottom of the pond is not disturbed. Laser levels or GIS based systems are to be used, following the as-constructed dimensions of the pond, to ensure that the sediment excavation does not exceed the bottom of the pond and disturb the liner.
- 4. Restore vegetation as per the Landscape Plans.

Sediment Disposal

Generally, sediment removed from SWMFs will not be contaminated to the point that it would be classified as hazardous waste. However, all sediment which is removed from SWMFs should be tested to determine disposal options. MECP sediment disposal requirements should be consulted for information pertaining to the exact parameters and acceptable levels for different disposal options. Most private laboratories are familiar with the disposal guidelines and can test sediment samples with these in mind.

For example, in order to deposit the sediment on land, it would need to meet inert fill requirements under *Regulation 347*. For landfill disposal, the sediment would have to be classified as non-hazardous, i.e., not leachate toxic according to TCLP leachate test in *Regulation 347* (effective March 31, 2001).

Off-site disposal of the sediment can mean disposal at a sanitary landfill or disposal at another area undergoing filling. The decision of where the material is deposited depends on the quality of the sediments and the availability and distance of the alternative fill areas.

Outlet Control Structure Cleanout

The outlet control structure in the SWMF has been designed with a concrete midwall, and an orifice and weir through the midwall. Upon inspection it must be ensured that the orifice has not been blocked, and that any debris be removed from the orifice. There is also the potential for sediment to build up on the pond side of the midwall. This should be pumped out by a vacuum truck if the sediment is built up from the bottom of the manhole halfway to the orifice.

Winter Operations

There are no special requirements for winter operation. However, periodically through the winter and prior to spring thaw, the small diameter orifice located in the control structure needs to be checked and cleared of any debris. This includes ensuring that any ice buildup or ice blockage in the orifice is cleared away.

Unscheduled/Emergency Maintenance

Failure of any feature impacting the operation of the stormwater facility should be rectified immediately to minimize impacts on the receiving watercourse. In case of pond or storm sewer failure, the following personnel should be notified immediately:

Personnel	Phone Number
Pantone Investment Management	1-647-993-3909

Conclusions

This report has identified the maintenance responsibilities and procedures required to efficiently maintain the Lot 31 Clark Street stormwater management facility and infrastructure.


Report Prepared By:


Clayton Capes, MSc. P.Eng.


CAPES Engineering Ltd.

Appendices


Appendix A – Erosion and Sediment Control Drawings











Appendix B – SWM Infrastructure Drawings











LEGEND	
× 221.21	PROPOSED ELEVATION
× 221.21	EXISTING ELEVATION
	CURB DEPRESSION
	MAXIMUM 3:1 SLOPE

UNLESS OTHERWISE NOTED

STORM SEWER/MANHOLE

SANITARY SINGLE HOUSE CONNECTION AND CLEANOUT
WATER SERVICE CONNECTION AND CURB STOP

LIVEDANIT 0.1/AL1/E

HYDRANT & VALVE

This drawing is the exclusive property of CAPES Engineering Ltd. The reproduction of any part without express written consent of this Corporation is strictly prohibited.
 The contractor shall verify all dimensions, levels, and datums on site and report any

discrepancies or omissions to CAPES Engineering Ltd. prior to construction.

3. This drawing is to be read and understood in conjunction with all other plans and documents applicable to this project.


No	Revision	Date
1	ISSUED FOR APPROVALS	22/12/08
2	REVISED FOR APPROVALS	23/12/07
3	REVISED FOR APPROVALS	24/06/28
4	REVISED FOR APPROVALS	24/11/14

NOTES:

TOPOGRAPHIC SURVEY PREPARED BY SMC GEOMATICS, ELEVATIONS SHOWN ARE GEODETIC

BENCHMARK: NAIL IN HYDRO POLE AT SOUTH END OF SUBJECT SITE, ELEVATION 185.392

BOUNDARY CONDITIONS SHOWN INTERPRETED FROM PLAN PREPARED BY VAN HARTEN SURVEYING INC., AND SHOWN APPROXIMATELY HEREIN. THIS IS NOT A PLAN OF SURVEY, AND CANNOT BE USED TO DEFINE SITE BOUNDARY CONDITIONS



PANTONE CAPITAL INC.

Lot 31 Clark St. Site Plan


STORMWATER MANAGEMENT FACILITY PLAN



signed GRIFFIN		Checked C. CAPES		Date 22/08/09
oject No. 121-185				Rev No. 4
ale 250	0	5.0	10.0	15.0m


Drawing No.

C6



C/CAPES 100056104





TOPOGRAPHIC SURVEY PREPARED BY SMC GEOMATICS, ELEVATIONS SHOWN ARE GEODETIC

BOUNDARY CONDITIONS SHOWN INTERPRETED FROM PLAN PREPARED BY VAN HARTEN SURVEYING INC., AND SHOWN APPROXIMATELY HEREIN. THIS IS NOT A PLAN OF SURVEY, AND

BENCHMARK: NAIL IN HYDRO POLE AT SOUTH END OF SUBJECT SITE, ELEVATION 185.392

CANNOT BE USED TO DEFINE SITE BOUNDARY CONDITIONS

. This drawing is the exclusive property of CAPES Engineering Ltd. The reproduction of

2. The contractor shall verify all dimensions, levels, and datums on site and report any

ISSUED FOR APPROVALS

REVISED FOR APPROVALS

REVISED FOR APPROVALS

REVISED FOR APPROVALS

22/12/08

23/12/07

24/06/28

24/11/14

any part without express written consent of this Corporation is strictly prohibited.

discrepancies or omissions to CAPES Engineering Ltd. prior to construction.

3. This drawing is to be read and understood in conjunction with all other plans and documents applicable to this project.



Lot 31 Clark St. Site Plan



Designed K. GRIFFIN	Check C. C	ked CAPES		Date 22/08/09	Drawing No.
Project No. 2021-185	<u> </u>	<i></i>		Rev No.	C7
Scale H 1:250 V 1:25	0	5.0	10.0	15.0n	n

STORMWATER MANAGEMENT FACILITY PROFILE

GEORGIAN BAY

SUBJECT SITE-

<u>LEGEND</u>

PROPOSED ELEVATION

EXISTING ELEVATION

CURB DEPRESSION

MAXIMUM 3:1 SLOPE UNLESS OTHERWISE NOTED

CLEANOUT

HYDRANT & VALVE

STORM SEWER/MANHOLE


SANITARY SINGLE HOUSE CONNECTION AND


WATER SERVICE CONNECTION AND CURB STOP


× 221.21


× 221.21


KEY PLAN





















l	Notes
	1. This drawing is the exclusive property of CAPES Engineering Ltd. The reproduction of any part without express written consent of this Corporation is strictly prohibited.
	2. The contractor shall verify all dimensions, levels, and datums on site and report any

any part without express written consent of this Corporation is strictly prohibited.			
The contractor shall verify all dimensions, levels, and datums on site and report any discrepancies or omissions to CAPES Engineering Ltd. prior to construction.		ISSUED FOR APPROVALS	22/12/08
		REVISED FOR APPROVALS	23/12/07
This drawing is to be read and understood in conjunction with all other plans and documents applicable to this project.		REVISED FOR APPROVALS	24/06/28
		REVISED FOR APPROVALS	24/11/14

No Revision


NOTES: TOPOGRAPHIC SURVEY PREPARED BY SMC GEOMATICS, ELEVATIONS SHOWN ARE GEODETIC BENCHMARK: NAIL IN HYDRO POLE AT SOUTH END OF SUBJECT SITE, ELEVATION 185.392 BOUNDARY CONDITIONS SHOWN INTERPRETED FROM PLAN PREPARED BY VAN HARTEN SURVEYING INC., AND SHOWN APPROXIMATELY HEREIN. THIS IS NOT A PLAN OF SURVEY, AND CANNOT BE USED TO DEFINE SITE BOUNDARY CONDITIONS





Client	
PANTONE CAPITAL INC.	Lot 31 Clark St. Site Plan
	STANDARD DETAILS





K. GRIFFIN C. CAPES 22/08/09 2021-185 AS NOTED




















Slope 1% min ─


Fittings or radius bends —

as required










This drawing is to be read and understood in conjunction with all other plans and documents applicable to this project.	

f	No	Revision	Date
	1	ISSUED FOR APPROVALS	22/12/08
	2	REVISED FOR APPROVALS	23/12/07
	3	REVISED FOR APPROVALS	24/06/28
	4	REVISED FOR APPROVALS	24/11/14

NOTES: TOPOGRAPHIC SURVEY PREPARED BY SMC GEOMATICS, ELEVATIONS SHOWN ARE GEODETIC BENCHMARK: NAIL IN HYDRO POLE AT SOUTH END OF SUBJECT SITE, ELEVATION 185.392 BOUNDARY CONDITIONS SHOWN INTERPRETED FROM PLAN PREPARED BY VAN HARTEN SURVEYING INC., AND SHOWN APPROXIMATELY HEREIN. THIS IS NOT A PLAN OF SURVEY, AND CANNOT BE USED TO DEFINE SITE BOUNDARY CONDITIONS






Lot 31 Clark St. Site Plan STANDARD DETAILS



	Designed	Checked	Date
	K. GRIFFIN	C. CAPES	22/08/
	Project No.		Rev No.
WNLINE	2021-185		4
	Scale		,
	AS NOTED		

Drawing No.




Retaining and restraining devices shall be as specified. A Bond breaker shall be used between the concrete and the fittings and


B Bolts and nuts for buried flange to flange connections shall be stainless steel. C When required, flange of standpipe extensions shall not be in frost zone.

D This OPSD shall be read in conjunction with OPSD 1103.010 and 1103.020. E Backfill material within 500mm of service box shall be native or imported, as specified. F Tracer wire shall be installed as specified.

G All dimensions are in millimetres unless otherwise shown.


Nov 2018 Rev 3 ONTARIO PROVINCIAL STANDARD DRAWING HYDRANT INSTALLATION OPSD 1105.010







TYPICAL SWALE


N.T.S.








TEMPORARY INTERCEPTOR SWALE N.T.S.





Notes
1. This drawing is the exclusive property of CAPES Engineering Ltd. The reproduction of any part without express written consent of this Corporation is strictly prohibited.
2. The contractor shall verify all dimensions, levels, and datums on site and report any


	discrepancies of offissions to CAI ES Engineering Eta. prior to construction.
3.	This drawing is to be read and understood in conjunction with all other plans and documents applicable to this project. $ \\$


No	Revision	Date
1	ISSUED FOR APPROVALS	22/12/08
2	REVISED FOR APPROVALS	23/12/07
3	REVISED FOR APPROVALS	24/06/28
4	REVISED FOR APPROVALS	24/11/14

NOTES: TOPOGRAPHIC SURVEY PREPARED BY SMC GEOMATICS, ELEVATIONS SHOWN ARE GEODETIC BENCHMARK: NAIL IN HYDRO POLE AT SOUTH END OF SUBJECT SITE, ELEVATION 185.392 BOUNDARY CONDITIONS SHOWN INTERPRETED FROM PLAN PREPARED BY VAN HARTEN

CANNOT BE USED TO DEFINE SITE BOUNDARY CONDITIONS

SURVEYING INC., AND SHOWN APPROXIMATELY HEREIN. THIS IS NOT A PLAN OF SURVEY, AND





CAST IN PLACE CONCRETE NOTES:

FOR WORK OF OTHER SECTIONS.

GRADE 400R.

REINFORCING STEEL.

THAN 15 DEGREES CELSIUS.

15M HORIZONTAL

LAP SPLICE VERTICAL

CONTINUOUS WATERSTOP-

STEEL

BUTYL SEAL -IN PC JOINTS

BASE SEE

OPSD 701.051

TOLERANCÈS, AND FINISHING CONCRETE.

AGGREGATE TO BE 20mm DIAMETER. 1.3. AIR-ENTRAINING ADMIXTURE: TO ASTM C260.

GENERAL 1. CONFORM TO CSA — A23 SERIES OF STANDARDS, AND THE RSIC MANUAL OF STANDARD PRACTICE (LATEST EDITION) FOR DESIGN, MATERIALS, CONSTRUCTION, CURING, TESTING,

1.2. WATER, FINE AGGREGATES, COARSE AGGREGATES: TO CSA-A23.1. MAXIMUM COARSE

1.5. CURING-SEALING COMPOUND: WHEN WATER CURING IS NOT PRACTICAL AS APPROVED BY

1.6. HYDROPHILLIC TYPE WATERSTOP: HYDROTITE CJK - BY MME MULTIURETHANES (1 800 663 $|\hspace{-.1em}|$

1.7. REINFORCING STEEL: NEW, DEFORMED, BILLET-STEEL BARS TO CSA STANDARDS G30.18,

SUPPLY CONCRETE AS PER CSA A23.1-09, PERFORMANCE BASED SPECIFICATION CLEARLY COORDINATING MIX DESIGNATIONS WITH STRUCTURAL AND ARCHITECTURAL CRITERIA FOUND

WITHIN THE CONTRACT DOCUMENTS. FOR ALL CONCRETE MIXES CLEARLY IDENTIFY AND CONFIRM THE UNDERSTANDING OF THE CONCRETE REQUIREMENTS IN WRITING PRIOR TO

PRODUCTION FOR ALL MIXES. SUCH A SUBMISSION SHALL INCLUDE, AS A MINIMUM; THE

LOCATION OF EACH MIX DESIGN TO BE USED IN THE STRUCTURE, THE CEMENT TYPE, ALL

SUPPLEMENTARY MATERIALS, CLASS OF EXPOSURE, COMPRESSIVE STRENGTHS, AGGREGATE SIZE, AND CONCRETE DENSITY. USE READY-MIXED CONCRETE TO GIVE MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 35 MPa @ 28 DAYS, WITH EXPOSURE CLASS C1. COORDINATE WITH THE GENERAL CONTRACTOR WITH RESPECT TO WORKABILITY ISSUES, AND CONFIRM THE CRITERIA IN THE SUBMISSION (SLUMP, PUMP MIX, DESIGN CONCRETE TEMPERATURE, ETC.).

PROVIDE STEEL CHAIRS OR CONCRETE SPACERS TO MAINTAIN SPECIFIED 60mm COVER TO

AND COLD JOINTS, CHIPS AND SPALLS. PATCH DEFECTS AND TIE HOLES.

CONCRETE SHALL BE FREE FROM HONEYCOMBING, VOIDS, LOSS OF FINES, VISIBLE FLOW LINES

LAP ALL REINFORCING WITH CLASS B' SPLICES U/N. ALL STEEL MUST BE ADEQUATELY TIED AND ACCURATELY PLACED PRIOR TO THE COMMENCEMENT OF ANY CONCRETE POUR.

PROTECT FRESH CONCRETE FROM PREMATURE DRYING, SUNSHINE, EXCESSIVELY HOT OR COLD

TEMPERATURE FOR AS LONG AS REQUIRED FOR HYDRATION OF THE CEMENT AND CURING OF

THE CONCRETE. REFER TO CSA A23.1 FOR HOT AND COLD WEATHER CONCRETING PRACTICES.

PROTECT FRESH CONCRETE FROM COLD TEMPERATURES BELOW 5 DEGREES CELSIUS. PROVIDE

- CONTINUOUS HYDROPHILLIC TYPE WATERSTOP CLOSE TO MID-THICKNESS

10M DOWEL X 350 LONG HORIZONTAL

GROUT INTO MANHOLE USING HILTI

LAP WITH HORIZONTAL STEEL.

____60mm MIN. CONCRETE COVER TO STEEL

OFFSET TO AVOID BASE REINFORCING

— ELEVATION

- WATERSTOP

- 75ø ORIFICE INV = 184.00SEE CIVIL

> – 90mm MIN. DOWEL EMBEDMEN1

PLANS

<u>10M X 50</u>0 DOWELS @

250 C/C VERTICAL GROUT WITH HILTI

"ICE" EPOXY RESIN

185.05

-10M @ 250 AT C/C EACH WAY

- FORM ORIFICE

-10M X 500 DOWELS

15M HORIZONTAL

@ TOP

OF WALL

- 40mm EMBEDMENT

"ICE" EPOXY RESIN.

— 25mm CHAMFER TOP EDGE

TEMPORARY HEAT FOR A MINIMUM OF 3 DAYS TO MAINTAIN A TEMPERATURE OF GREATER

TEMPERATURES AND MECHANICAL INJURY. MAINTAIN AT A RELATIVELY CONSTANT

DETAIL X

SECTION Y

N.T.S.

N.T.S.

THE ENGINEER, USE A CLEAR LIQUID PRODUCT TO ASTM C-309, TYPE 1. USE SEALTIGHT

1.1. CEMENT GENERAL TYPE GU PORTLAND CEMENT TO CSA A3001.

1.4. CHEMICAL ADMIXTURES: TO ASTM C494 OR ASTM C1017.

VOCOMP20 BY W.R. MEADOWS OF CANADA LIMITED.

XECUTION
. USE VIBRATORS FOR CONSOLIDATION OF CONCRETE.


INSTALL, OR SUPPLY AND INSTALL, ANCHORAGE, FASTENINGS AND BLOCKING AS REQUIRED,





	Designed	Checked	Date	Drawing No.
	K. GRIFFIN	C. CAPES	22/08/09	
	Project No.		Rev No.	~
OUNTAINS - EUPHRASIA TOWNLINE	2021-185		4	
N NOH 1JO	Scale]
GINEERING.COM	AS NOTED			

SECTION Z-Z

N.T.S.








Notes	
 This drawing is the exclusive property of CAPES Engineering Ltd. The reproduction any part without express written consent of this Corporation is strictly prohibited 	
2. The contractor shall verify all dimensions, levels, and datums on site and report	any

WALL (TYP.)

	discrepancies or omissions to CAPES Engineering Ltd. prior to construction.
3.	This drawing is to be read and understood in conjunction with all other plans and documents applicable to this project.

No	Revision	Date
1	ISSUED FOR APPROVALS	22/12/08
2	REVISED FOR APPROVALS	23/12/07
3	REVISED FOR APPROVALS	24/06/28
4	REVISED FOR APPROVALS	24/11/14

NOTES: TOPOGRAPHIC SURVEY PREPARED BY SMC GEOMATICS, ELEVATIONS SHOWN ARE GEODETIC BENCHMARK: NAIL IN HYDRO POLE AT SOUTH END OF SUBJECT SITE, ELEVATION 185.392 BOUNDARY CONDITIONS SHOWN INTERPRETED FROM PLAN PREPARED BY VAN HARTEN SURVEYING INC., AND SHOWN APPROXIMATELY HEREIN. THIS IS NOT A PLAN OF SURVEY, AND CANNOT BE USED TO DEFINE SITE BOUNDARY CONDITIONS



CDS PMSU2015-4-C DESIGN NOTES

N.T.S.

SITE SPECIFIC DATA REQUIREMENTS

ATER QUALITY FLOW RATE (CFS OR L/s)

PEAK FLOW RATE (CFS OR L/s)

RETURN PERIOD OF PEAK FLOW (YRS)

**RETURN PERIOD OF PEAK FLOW (YRS)

 PIPE DATA:
 I.E.
 MATERIAL
 DIAMETER

 INLET PIPE 1
 *
 *
 *

 INLET PIPE 2
 *
 *
 *

 OUTLET PIPE
 *
 *
 *

ANTI-FLOTATION BALLAST WIDTH HEIGHT

NOTES/SPECIAL REQUIREMENTS:

CREEN APERTURE (2400 OR 4700)

PER ENGINEER OF RECORD

CDS PMSU2015-4-C

INLINE CDS

STANDARD DETAIL

Lot 31 Clark St. Site Plan STANDARD DETAILS

22/08/09



RASIA TOWNLINE	Designed K. GRIFFIN	Checked C. CAPES
IRASIA TOWNLINE	Project No. 2021-185	
	Scale	

Appendix C – Inspection Checklist


Lot 31 Clark Street – Town of The Blue Mountains SWM Monitoring Checklist

Date:

	ltem	Maintenance	Comments
		Required	
		(Y/N)	
SWN	1F		
1.	Outlet Blockage – If the SWMF has not drained down to empty 48 hours after a 25 mm rainfall check & remove any blockages in the control manhole.		
2.	Inlet Blockage - If there is sediment backing up into the basin inlet pipes, it is time to clean out the basin.		
3.	Sediment Depth – If maximum depth of 0.5 m of sediment has collected in main cell, and if sediment is backing up into inlet pipes, the facility will need to be cleaned out.		
4.	Observe SWMF vegetation. If the vegetation is dead/dying remove and replace the vegetation as per landscape plan		
5.	Trash Build-up – Any trash/debris around the headwalls at the inlets and outlets will need to be removed.		
6.	Berm Stability – If there are any signs of cracking or slumping call the Engineer or Geotechnical Consultant		
7.	Outlet Structure – Raise control manhole lid and check for free flow. Remove any blockages that may be prohibiting free flow through orifice or over weir. Pump out sediment built up on pond side of midwall with vacuum truck.		

8.	Downstream of Basin - Any signs of erosion and seepage through the berm may indicate the need to repair an issue. Contact the Engineer or a Geotechnical Engineer	
9.	Maintenance Access – Check to ensure road is in fair condition and restore road as necessary.	
Stori	m Sewer	
10.	Manholes and Catchbasins – Remove manhole cover, if sediment exceeds half the sump depth, remove sediment with vacuum truck	
11.	Flush Pipe System – Once per year for first 5 years. Beyond first 5 years, if standing water is noted in connecting MHs, flush and use vacuum truck to remove sediments	
Vege	tated Swale	I
12.	Check for accumulated sediment. If sediment depth exceeds 0.05 m clean out.	
13.	Check for erosion or vegetation dye off. Repair as required.	
OGS	Units	
14.	Check sediment and oil storage and pump out as per Manufacturers recommendations	

Appendix D – Landscape Drawings





GENERAL NOTES

CONTRACTOR IS RESPONSIBLE FOR ALL LOCATES INCLUDING ALL UNDERGROUND SERVICES PRIOR TO ANY EXCAVATION OR INSTALLATIONS. THE CONTRACTOR IS REQUIRED TO NOTIFY THE VARIOUS UTILITY COMPANIES 48 HOURS PRIOR TO THE COMMENCEMENT OF ANY WORK.

ANY ACCOMPANYING DOCUMENTATION RELATING TO THE LANDSCAPE PLAN AND/OR PRESERVATION PLAN SUCH AS TENDER DOCUMENTS AND CHANGE NOTICES ARE TO BE ENDORSED BY J.D.B. ASSOCIATES LIMITED PRIOR TO THE BEGINNING OF ANY SITE WORKS. IN THE EVENT THAT OF A DISCREPANCY THE DRAWING SHALL BE ASSUMED CORRECT.

IT IS THE RESPONSIBILITY OF THE PERSON OR PERSONS RESPONSIBLE FOR THE CONSTRUCTED WORKS TO NOTIFY THE LANDSCAPE ARCHITECT WHEN PREPARED FOR ANY REQUIRED INSPECTIONS AND SIGN OFFS.

SCHEDULED MEETINGS SHALL TAKE PLACE AT THE CLOSEST MUTUALLY CONVENIENT TIME.

No.	REVISION	DATE	APRVD
1.	CLIENT REVIEW	December 6 th , 2022	StT
2.	AS PER TOWN COMMENTS	December 27 th , 2023	StT
3.	AS PER TOWN COMMENTS	May 28 th , 2024	StT
4.	AS PER TOWN COMMENTS	August 1st, 2024	StT
5.	AS PER UPDATED SITE PLAN	November 14 th , 2024	StT

ALL DRAWINGS AND SPECIFICATIONS ARE INSTRUMENTS OF SERVICE AND ARE THE PROPERTY OF JDB ASSOCIATES LIMITED. DRAWINGS ARE NOT TO BE MODIFIED AND/OR REPRODUCED WITHOUT THE WRITTEN CONSENT OF JDB ASSOCIATES LIMITED. REPRODUCTION OF DRAWINGS IN ANY FORM WITHOUT THE CONSENT OF JDB ASSOCIATES LIMITED VOIDS THE DRAWING AT WHICH TIME JDB ASSOCIATES LIMITED ACCEPTS NO LIABILITY FOR THE DRAWING CONTENT OR WORKS RESULTING FROM SAID REPRODUCTION. DRAWINGS MAY BE REPRODUCED BY MUNICIPAL AND GOVERNMENT AGENCIES RESPONSIBLE FOR APPROVALS FOR THEIR OWN USE. JDB ASSOCIATES RESERVES THE RIGHT TO WITHDRAW ANY DRAWING(S) FROM GOVERNMENT OR MUNICIPAL AGENCIES WHETHER APPROVED OR NOT IN THE EVENT THAT ACCOUNTS ARE NOT SETTLED OR REMAIN OUTSTANDING.

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY ALL DIMENSIONS ON THE SITE AND REPORT ANY DISCREPANCIES OR VARIATIONS FROM THE SUPPLIED INFORMATION TO THE LANDSCAPE ARCHITECT WITH THE PROJECT. JDB ASSOCIATES LIMITED IS NOT RESPONSIBLE FOR THE ACCURACY OF SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR ELECTRICAL INFORMATION SHOWN ON THE DRAWING. FOR FURTHER INFORMATION REFER TO APPROPRIATE SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR

ELECTRICAL DRAWINGS PRIOR TO PROCEEDING WITH ANY WORKS.


THIS DRAWING IS NOT TO BE SCALED.

BASE PLAN REVISED: MARCH, 2022

Client info:

IPS- INNOVATIVE PLANNING SOLUTIONS 647 Welham Road, Unit 9A, Barrie, ON, L4N 0B7


ACCEPTED BY:



JDB associates LTD.

Urban Designers Landscape Architects Arborists

274 Burton Ave., Suite 1201 Barrie, Ontario L4N 5W4




Fax: 705-722-5660 Tel: 705-722-6278

LOT 31 CLARK ST

Town of the Blue Mountains, ON

TREE INVENTORY/ PRESERVATION PLAN

SCALE:	DESIGNED BY:	REVIEWED BY:
1 : 600	IT	NB
TOWN FILE No.	OUR FILE REF. # 14-22	



D1 - TREE PRESERVATION / SNAKE FENCE (REFER TO SNAKE FENCE NOTES)

THE INTENT OF TREE PRESERVATION AND PROTECTION IS TO PROVIDE AN INVENTORY OF EXISTING TREES ON SITE. IT IS NOT A SURVEY AND THEREFORE THE EXACT LOCATION OF EXISTING TREES MUST BE VERIFIED ON SITE PRIOR TO THE COMMENCEMENT OF ANY CONSTRUCTION WORKS.

ALL TREES TO BE PRESERVED SHALL BE INDICATED AND MARKED AS SUCH ON SITE BY THE LANDSCAPE ARCHITECT PRIOR TO THE SITE DEVELOPMENT.

AS PART OF THE CLEARING AND GRUBBING, TREES LOCATED AT THE EDGES OF STANDS ABUTTING RESIDENTIAL ARE ARE TO BE PRUNED OF DEAD AND DISEASED LIMBS. PRUNING TO BE COMPLETED IN ACCORDANCE TO ACCEPTED HORTICULTURAL PRACTICES AND TO THE SATISFACTION OF THE LANDSCAPE ARCHITECT.

IN THE EVENT THAT A TREE THAT HAS BEEN DESIGNATED FOR PRESERVATION IS DAMAGED OR REMOVED WITHOUT PRIOR WRITTEN PERMISSION FROM THE TOWN, THE LAND OWNER SHALL BE RESPONSIBLE FOR THE REPLACEMENT OF SAID TREE WITH TREES OF EQUAL CALIPER VALUE AND COMPARABLE SPECIES, TO THE SATISFACTION OF THE THE TOWN AND THE LANDSCAPE ARCHITECT.

SPECIFICATIONS FOR PRESERVATION & PROTECTION

PRIOR THE COMMENCEMENT OF ANY CONSTRUCTION WORKS, ALL TREES OR BLOCKS OF TREES THAT HAVE BEEN DESIGNATED FOR PRESERVATION, AS INDICATED ON THE ACCOMPANYING PLAN SHALL BE FULLY PROTECTED BY THE ERECTION OF HOARDING OUTSIDE OF OR AT THE DRIP LINE (SEE DETAIL). AREAS WITHIN THE HOARDING SHALL BE CLEARED AND GRUBBED ONLY UNDER THE WRITTEN DIRECTION AND SUPERVISION OF THE LANDSCAPE ARCHITECT.

EQUIPMENT OR VEHICLES SHALL NOT BE PARKED, REPAIRED OR REFUELED WITHIN TREE PROTECTION ZONE, CONSTRUCTION MATERIALS SHALL NOT BE STORED AND EARTH MATERIALS SHALL NOT BE STOCKPILED WITHIN THE DRIP LINE AREA OF ANY TREE NOT DESIGNATED FOR REMOVAL.

ANY TREES NOT DESIGNATED FOR REMOVAL SHALL NOT HAVE RIGGING CABLES ATTACHED OR WRAPPED AROUND THEM NOR SHALL ANY CONTAMINANTS BE DUMPED WITHIN THE PROTECTIVE AREAS. FURTHER, NO CONTAMINANTS SHALL BE DUMPED OR FLUSHED WHERE THEY MAY COME INTO CONTACT WITH THE FEEDER ROOTS OF THE TREES TO BE PRESERVED.

THE CONTRACTOR OR LAND OWNER SHALL TAKE EVERY PRECAUTION TO PREVENT DAMAGE TO TREES OR SHRUBS THAT ARE NOT DESIGNATED FOR REMOVAL AS PER THE ACCOMPANYING PLAN.

SINCES THAT THE TOT BESTOWNED TOKKEMOVAE AS TEK THE MOCOMITATION TEAT.

UNLESS THE CONTRACT WORK SPECIFICALLY REQUIRES WORK WITHIN THE DRIP LINE OF TREES NOT DESIGNATED FOR REMOVAL, EQUIPMENT SHALL NOT BE OPERATED WITHIN THAT DRIP LINE AREA. WHEN CONTRACT WORK MUST BE COMPLETED WITHIN THE DRIP LINE OF TREES NOT DESIGNATED FOR REMOVAL, OPERATION OF EQUIPMENT WITHIN THAT DRIP LINE SHALL BE KEPT TO THE MINIMUM AMOUNT REQUIRED TO COMPLETE THE WORKS. PRIOR TO THE COMMENCEMENT OF SUCH WORKS THE LANDSCAPE ARCHITECT MUST BE GIVEN WRITTEN NOTIFICATION AND WILL SUBSEQUENTLY BE REQUIRED TO INSPECT SAID WORKS.


THE CONTRACTOR'S OPERATION SHALL IN NO WAY CAUSE DAMAGE TO THE TRUNK OR BRANCHES OF TREES NOT DESIGNATED FOR REMOVAL.

THE CONTRACTOR'S OPERATION SHALL NOT CAUSE FLOODING OR SEDIMENT DEPOSITS IN AREAS WHERE TREES ARE NOT DESIGNATED FOR REMOVAL.

IN THE EVENT THAT IT IS NECESSARY TO REMOVE LIMBS OR PORTIONS OF TREES NOT DESIGNATED FOR REMOVAL, WRITTEN APPROVAL AND DIRECTION MUST BE GIVEN BY THE LANDSCAPE ARCHITECT PRIOR TO ANY WORKS. THE REMOVALS MUST BE EXECUTED CAREFULLY AND IN ACCORDANCE WITH STANDARD HORTICULTURAL PRACTICES AND TECHNIQUES.

NO GRADING SHALL TAKE PLACE WITHIN THE PRESERVATION ZONE.

D3 - NOTES FOR PRESERVATION AND PROTECTION



THE DRIP LINE OF VEGETATION IS CONSIDERED THE LIMIT OF PRESERVATION.

NOTES

CHANGES OR MODIFICATIONS TO THE LIMIT OF PRESERVATION MUST BE APPROVED IN WRITING BY THE LANDSCAPE ARCHITECT AND MUST BE PROVIDED PRIOR TO ANY WORK TO OR WITHIN THE PRESERVATION ZONE.

TREE LIMBS THAT WILL INTERFERE WITH CONSTRUCTION OR SITE ACCESS MUST BE REMOVED USING STANDARD HORTICULTURAL PRACTICES.

"DRIP LINE" IS DEFINED AS THE PERIMETER EXTENT OF THE CROWN OR CANOPY.

FOR FURTHER INFORMATION REFER TO TREE PROTECTION & PRESERVATION NOTES AND SPECIFICATIONS.

CLEARING AND GRUBBING WITHIN THE PRESERVATION ZONE MAY ONLY BE DONE UNDER THE SUPERVISION OF THE LANDSCAPE ARCHITECT.

NO CLEARING OR GRUBBING IS PERMITTED WITHIN THE ENVIRONMENTAL PROTECTION AREA.

D2 - LIMIT OF TREE PRESERVATION DETAIL

1. PROTECTION AREA IS INITIALLY IDENTIFIED IN THE FIELD BY A LICENSED ONTARIO SURVEYOR. THIS LINE APPROXIMATELY ESTABLISHES THE LIMITS OF TREE PRESERVATION SUBJECT TO AN ON-SITE MEETING WITH TOWN OF BLUE MOUNTAINS PARKS PLANNING STAFF AND THE LANDSCAPE ARCHITECT/ARBORIST.

2. THE LANDSCAPE ARCHITECT/ARBORIST AND THE TOWN OF BLUE MOUNTAINS PARKS PLANNING STAFF MEET TO REVIEW THE SURVEYED LINE PRIOR TO ANY TREE REMOVAL OCCURRING, AND TO ADJUST THE LINE WHERE APPROPRIATE TO REFLECT THE ACTUAL NATURE OF A TREED AREA AS OPPOSED TO A STRAIGHT CUT LINE

3. TREES THAT ARE SUSCEPTIBLE TO FALLING ONTO PRIVATE PROPERTY OR MUNICIPAL PROPERTY FROM WITHIN THE TREE PRESERVATION ZONE WILL BE IDENTIFIED FOR REMOVAL. REMOVAL WILL TAKE PLACE AS PRESCRIBED IN ITEM #6 BELOW.

4. ONCE THE SITE VISIT HAS CONCLUDED, THEN TREE PRESERVATION FENCING WILL BE ERECTED ALONG THE AGREED TREE PRESERVATION LINE.

5. FULL TREE REMOVAL OUTSIDE OF THE TREED AREAS MAY OCCUR ONCE THE PRESERVATION FENCING HAS BEEN ERECTED AND ALL REQUIRED TREE REMOVAL PERMITTING IS ISSUED.

6. TREES ARE TO BE FELLED IN SUCH A MANNER AS TO NOT DISTURB VEGETATION TO REMAIN. NO MACHINERY OR EQUIPMENT SHALL BE OPERATED OR STORED WITHIN THE DRIPLINE OF PROTECTED TREES.

7. STUMP REMOVALS ARE TO BE IMPLEMENTED AS TO NOT TO DISTURB THE GROUND WITHIN THE TREE PRESERVATION ZONE.

8. ONCE TREE REMOVAL HAS OCCURRED, AND PRIOR TO THE ISSUANCE OF THE UNDERGROUND CERTIFICATE, A RE-INSPECTION OF THE TREE PRESERVATION AREAS MUST OCCUR WITH TOWN OF BLUE MOUNTAINS STAFF AND THE LANDSCAPE ARCHITECT/ARBORIST. ANY ADDITIONAL TREES TO BE REMOVED WILL BE NOTED BY THE TOWN OF BLUE MOUNTAINS PARKS PLANNING STAFF AND LANDSCAPE ARCHITECT/ARBORIST.

9. ALL TREES ON ADJACENT PRIVATE LAND SHALL RECEIVE DRIPLINE PROTECTION.

TREE PRESERVATION PROCESS

NOTE:

NO TREE CUTTING SHALL OCCUR BETWEEN APRIL 1st AND OCTOBER 31st UNLESS CLEARANCE FROM M.N.R. AND M.E.C.P. IS PROVIDED.



GENERAL NOTES

CONTRACTOR IS RESPONSIBLE FOR ALL LOCATES INCLUDING ALL UNDERGROUND SERVICES PRIOR TO ANY EXCAVATION OR INSTALLATIONS. THE CONTRACTOR IS REQUIRED TO NOTIFY THE VARIOUS UTILITY COMPANIES 48 HOURS PRIOR TO THE COMMENCEMENT OF ANY WORK.

ANY ACCOMPANYING DOCUMENTATION RELATING TO THE LANDSCAPE PLAN AND/OR PRESERVATION PLAN SUCH AS TENDER DOCUMENTS AND CHANGE NOTICES ARE TO BE ENDORSED BY J.D.B. ASSOCIATES LIMITED PRIOR TO THE BEGINNING OF ANY SITE WORKS. IN THE EVENT THAT OF A DISCREPANCY THE DRAWING SHALL BE ASSUMED CORRECT.

IT IS THE RESPONSIBILITY OF THE PERSON OR PERSONS RESPONSIBLE FOR THE CONSTRUCTED WORKS TO NOTIFY THE LANDSCAPE ARCHITECT WHEN PREPARED FOR ANY REQUIRED INSPECTIONS AND SIGN OFFS.

SCHEDULED MEETINGS SHALL TAKE PLACE AT THE CLOSEST MUTUALLY CONVENIENT TIME.

No.	REVISION	DATE	APRVD
1.	CLIENT REVIEW	December 6 th , 2022	StT
2.	AS PER TOWN COMMENTS	December 27 th , 2023	StT
3.	AS PER TOWN COMMENTS	May 28 th , 2024	StT
4.	AS PER TOWN COMMENTS	August 1st, 2024	StT
5.	AS PER UPDATED SITE PLAN	November 14 th , 2024	StT


ALL DRAWINGS AND SPECIFICATIONS ARE INSTRUMENTS OF SERVICE AND ARE THE PROPERTY OF JDB ASSOCIATES LIMITED. DRAWINGS ARE NOT TO BE MODIFIED AND/OR REPRODUCED WITHOUT THE WRITTEN CONSENT OF JDB ASSOCIATES LIMITED. REPRODUCTION OF DRAWINGS IN ANY FORM WITHOUT THE CONSENT OF JDB ASSOCIATES LIMITED VOIDS THE DRAWING AT WHICH TIME JDB ASSOCIATES LIMITED ACCEPTS NO LIABILITY FOR THE DRAWING CONTENT OR WORKS RESULTING FROM SAID REPRODUCTION.

DRAWINGS MAY BE REPRODUCED BY MUNICIPAL AND GOVERNMENT AGENCIES RESPONSIBLE FOR APPROVALS FOR THEIR OWN USE.

JDB ASSOCIATES RESERVES THE RIGHT TO WITHDRAW ANY DRAWING(S) FROM GOVERNMENT OR MUNICIPAL AGENCIES WHETHER APPROVED OR NOT IN THE EVENT THAT ACCOUNTS ARE NOT SETTLED OR REMAIN OUTSTANDING.

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY ALL DIMENSIONS ON THE SITE AND REPORT ANY DISCREPANCIES OR VARIATIONS FROM THE SUPPLIED INFORMATION TO THE LANDSCAPE ARCHITECT WITH THE PROJECT. JDB ASSOCIATES LIMITED IS NOT RESPONSIBLE FOR THE ACCURACY OF SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR ELECTRICAL INFORMATION SHOWN ON THE DRAWING. FOR FURTHER INFORMATION REFER TO APPROPRIATE SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR ELECTRICAL DRAWINGS PRIOR TO PROCEEDING WITH ANY WORKS.

THIS DRAWING IS NOT TO BE SCALED.




ACCEPTED BY:



JDB associates LTD

Urban Designers
Landscape Architects
Arborists

274 Burton Ave., Suite 1201 Barrie, Ontario L4N 5W4




LOT 31 CLARK ST

TREE PRESERVATION DETAILS


Town of the Blue Mountains, ON

SCALE:	DESIGNED BY:	REVIEWED BY:
NTS	IT	NB
TOWN FILE No.	OUR FILE REF. # 14-22	



CODE	QNTY	COMMON NAME	BOTANICAL NAME	SIZE	FORM	SPACING	DETAIL	NOTES		
DECIDU					1					
As	6	SUGAR MAPLE	Acer saccharum	60 mm	W.B.	9.0 m o/c	D-1	Full Form/ Fall prunning only		
Co	5	COMMON HACKBERRY	Celtis occidentalis	60 mm	W.B.	9.0 m o/c	D-1	Full Form		
Gt	2	SHADEMASTER HONEYLOCUST	Gleditsia triacanthos var. inermis 'Shademaster'	60 mm	W.B.	9.0 m o/c	D-1	Full Form		
Ov	4	IRONWOOD	Ostrya virginiana	60 mm	W.B.	7.0 m o/c	D-1	Full Form/ Spring plant only		
Qa	8	WHITE OAK	Quercus alba	60 mm	W.B.	15.0 m o/c	D-1	Spring planting/ Soil pH<7.5		
CONIFEROUS TREES										
Pg	29	WHITE SPRUCE	Picea glauca	200cm	w.b.	5m o/c	D-2	Full form / Do not cut leader		
Jv	12	EASTERN RED CEDAR	Juniperus virginiana	200cm	w.b.	2.5m o/c	D-2	Full form / Do not cut leader		
Ps	7	EASTERN WHITE PINE	Pinus strobus	150 cm	w.b.	6m o/c	D-2	Full form / Do not cut leader		
SHRUB	S									
Aaln	12	SERVICE-BERRY	Amelanchier alnifolia	60 cm	3 gal	1.8m o/c	D-3	Full form / Container grown		
Jc	8	CANADIAN JUNIPER	Juniperus communis var. depressa	40cm	3 gal	1.5m o/c	D-2	Full form / Container grown		
JsM	3	MOFFET JUNIPER	Juniperus scopulorum 'Moffettii'	150cm	w.b.	1.5 m o/c	D-3	Full form / Container grown		
NATIV	E PER	ENNIALS			T.					
Rh	64	BLACK EYED SUSAN	Rudbeckia hirta	1 gal	pot	0.90 m o/c	n/a	Full form / Container grown		
SITE I	PLAN	PLANT LIST. REFER TO DETAILS AND	NOTES ON LP-2							
DECIDU	JOUS					1				
Ar	3	RED MAPLE	Acer rubrum	60 mm	W.B.	9.0 m o/c	D-1	Full Form/ Fall prunning only		
Asn	3	SILVER MAPLE	Acer saccharinum	60 mm	W.B.	9.0 m o/c	D-1	Full Form/ Fall prunning only		
Co	3	COMMON HACKBERRY	Celtis occidentalis	60 mm	W.B.	9.0 m o/c	D-1	Full Form		
Qr	5 ROUS	RED OAK 5 TREES	Quercus rubra	60 mm	W.B.	9.0 m o/c	D-1	Spring planting/ Soil pH<7.5		
					1		T			
Ab	8	BALSAM FIR	Abies balsamea	200cm	w.b.	6m o/c	D-2	Full form / Do not cut leader		
L1	5	AMERICAN LARCH	Larix laricina	200cm	w.b.	8.0m o/c	D-2	Full form / Do not cut leader		
NATIVI	E SHR	UBS								
Amel	21	BLACK CHOKEBERRY	Aronia melanocarpa	60 cm	3 gal	1.2m o/c	D-3	Full form / Container grown		
Asto	17	RUNNING JUNEBERRY	Amelanchier stolonifera	60 cm	3 gal	1.8m o/c	D-3	Full form / Container grown		
Came	7	AMERICAN HAZELNUT	Corylus americana	60 cm	3 gal	2.5m o/c	D-3	Full form / Container grown		
Popu	17	COMMON NINEBARK	Physocarpus opulifolius	60 cm	3 gal	1.8m o/c	D-3	Full form / Container grown		
Rpal	42	SWAMP ROSE	Rosa palustris	60 cm	3 gal	1.0m o/c	D-3	Full form / Container grown		
Vraf	18	DOWNY ARROW-WOOD	Viburnum rafinesquianum	60 cm	3 gal	1.5m o/c	D-3	Full form / Container grown		
Vtri	15	HIGH BUSH CRANBERRY	Viburnum trilobum	60 cm	3 gal	2.5m o/c	D-3	Full form / Container grown		
SWM	PON.	D PLANT LIST. REFER TO DETAILS AND	NOTES ON LP-2							
DECIDU	OUS	TREES								
Ar	5	RED MAPLE	Acer rubrum	45 mm	W.B.	9.0 m o/c	D-1	Full Form/ Fall prunning only		
As	2	SUGAR MAPLE	Acer saccharum	45 mm	W.B.	9.0 m o/c	D-1	Full Form/ Fall prunning only		
Asn	2	SILVER MAPLE	Acer saccharinum	60 mm	W.B.	9.0 m o/c	D-1	Full Form/ Fall prunning only		
Ov	3	IRONWOOD	Ostrya virginiana	45 mm	W.B.	7.0 m o/c	D-1	Full Form/ Spring plant only		
Qa	2	WHITE OAK	Quercus alba	45 mm	W.B.	15.0 m o/c	D-1	Spring planting/ Soil pH<7.5		
CONIFE	ROUS	TREES				1		, , , , , , , , , , , , , , , , , , , ,		
Pg	10	WHITE SPRUCE	Picea glauca	150 cm	w.b.	5m o/c	D-2	Full form / Do not cut leader		
Ps	17	EASTERN WHITE PINE	Pinus strobus	150 cm		6m o/c	D-2	Full form / Do not cut leader		
NATIVE			1	100 0111	.,	OIII		2 III Tomin 20 not out rouder		
					1	I				
Jc	21	CANADIAN JUNIPER	Juniperus communis var. depressa	40cm	3 gal	1.5m o/c	D-2	Full form / Container grown		
Popu	25	COMMON NINEBARK	Physocarpus opulifolius	50cm	3 gal	1.8m o/c	D-3	Full form / Container grown		
Rtyp	25 52	STAGHORN SUMAC AMERICAN YEW	Rhus typhina Taxus canadensis	80cm 40cm	3 gal	2.5m o/c 1.0 m o/c	D-3 D-3	Full form / Container grown Full form / Container grown		
Tax Vraf	54	DOWNY ARROW-WOOD			2 gal					
viai	34	DOWNI ARROW-WOOD	Viburnum rafinesquianum	50 cm	3 gal	1.5m o/c	D-3	Full form / Container grown		


RESTORATION PLANT LIST. REFER TO DETAILS AND NOTES ON LP-2




RESTORATION AREA

GENERAL LEGEND

PICNIC TABLE ON CONCRETE PAD (LP-3)



Estimated tree canopy size after 5 years



Estimated tree canopy size after 10 years



GENERAL NOTES

CONTRACTOR IS RESPONSIBLE FOR ALL LOCATES INCLUDING ALL UNDERGROUND SERVICES PRIOR TO ANY EXCAVATION OR INSTALLATIONS. THE CONTRACTOR IS REQUIRED TO NOTIFY THE VARIOUS UTILITY COMPANIES 48 HOURS PRIOR TO THE COMMENCEMENT OF ANY WORK.

ANY ACCOMPANYING DOCUMENTATION RELATING TO THE LANDSCAPE PLAN AND/OR PRESERVATION PLAN SUCH AS TENDER DOCUMENTS AND CHANGE NOTICES ARE TO BE ENDORSED BY J.D.B. ASSOCIATES LIMITED PRIOR TO THE BEGINNING OF ANY SITE WORKS. IN THE EVENT THAT OF A DISCREPANCY THE DRAWING SHALL BE ASSUMED CORRECT.

IT IS THE RESPONSIBILITY OF THE PERSON OR PERSONS RESPONSIBLE FOR THE CONSTRUCTED WORKS TO NOTIFY THE LANDSCAPE ARCHITECT WHEN PREPARED FOR ANY REQUIRED INSPECTIONS AND SIGN OFFS.

SCHEDULED MEETINGS SHALL TAKE PLACE AT THE CLOSEST MUTUALLY CONVENIENT TIME.

No.	REVISION	DATE	APRVD
1.	CLIENT REVIEW	December 6 th , 2022	StT
2.	AS PER TOWN COMMENTS	December 27 th , 2023	StT
3.	AS PER TOWN COMMENTS	May 28 th , 2024	StT
4.	AS PER TOWN COMMENTS	August 1st, 2024	StT
5.	AS PER UPDATED SITE PLAN	November 14 th , 2024	StT


ALL DRAWINGS AND SPECIFICATIONS ARE INSTRUMENTS OF SERVICE AND ARE THE PROPERTY OF JDB ASSOCIATES LIMITED. DRAWINGS ARE NOT TO BE MODIFIED AND/OR REPRODUCED WITHOUT THE WRITTEN CONSENT OF JDB ASSOCIATES LIMITED. REPRODUCTION OF DRAWINGS IN ANY FORM WITHOUT THE CONSENT OF JDB ASSOCIATES LIMITED VOIDS THE DRAWING AT WHICH TIME JDB ASSOCIATES LIMITED ACCEPTS NO LIABILITY FOR THE DRAWING CONTENT OR WORKS RESULTING FROM SAID REPRODUCTION. DRAWINGS MAY BE REPRODUCED BY MUNICIPAL AND GOVERNMENT AGENCIES RESPONSIBLE FOR APPROVALS FOR THEIR OWN USE. JDB ASSOCIATES RESERVES THE RIGHT TO WITHDRAW ANY DRAWING(S) FROM GOVERNMENT OR MUNICIPAL AGENCIES WHETHER APPROVED OR NOT IN THE EVENT THAT ACCOUNTS ARE NOT SETTLED OR REMAIN OUTSTANDING.

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY ALL DIMENSIONS ON THE SITE AND REPORT ANY DISCREPANCIES OR VARIATIONS FROM THE SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR ELECTRICAL INFORMATION SHOWN ON THE DRAWING. FOR FURTHER INFORMATION REFER TO APPROPRIATE SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR

ELECTRICAL DRAWINGS PRIOR TO PROCEEDING WITH ANY WORKS.

THIS DRAWING IS NOT TO BE SCALED.







JDB associates LTD.

Urban Designers Landscape Architects Arborists

274 Burton Ave., Suite 1201 Barrie, Ontario L4N 5W4


Fax: 705-722-5660 Tel: 705-722-6278


Town of the Blue Mountains, ON


LOT 31 CLARK ST

LANDSCAPE/ RESTORATION PLANTING PLAN

SCALE:	DESIGNED BY:	REVIEWED BY:
As shown	IT	NB
TOWN FILE No.	OUR FILE REF. # 14-22	LP-1







SHRUB PLANTING DETAIL

SEEDING AND TOP SOIL NOTES

SHORELINE ZONE

22% FOX SEDGE (Carex vulpinoidea

SEEDING RATE - 30kg PER HECTARE

SUPPLIED BY - OSC SEEDS 1-519-886-055

25% CANADA WILD RYE (Elymus canadensis)

23% FOWL MEADOWGRASS (Poa palustris)

25% SWITCHGRASS (Panicum virgatum)

UPLAND PLANTING ZONE

NO-MOW ZONE (INCLUDING ACCESS ROAD)

SIMCOE COUNTY NATIVE UPLAND MIXTURE

#7107 - SEASONALLY FLOODED ANNUAL/PERENNIAL MIXTURE 5% NODDING BUR MARIGOLD (Biddens ceruna

ANNUAL RYE NURSE CROP TO BE APPLIED AT TIME OF SEASONALL

GENERAL NOTES

CLIENT REVIEW

AS PER TOWN COMMENTS

AS PER TOWN COMMENTS

AS PER TOWN COMMENTS

AS PER UPDATED SITE PLAN

CONTRACTOR IS RESPONSIBLE FOR ALL LOCATES INCLUDING ALL

UNDERGROUND SERVICES PRIOR TO ANY EXCAVATION OR INSTALLATIONS.

ANY ACCOMPANYING DOCUMENTATION RELATING TO THE LANDSCAPE

PLAN AND/OR PRESERVATION PLAN SUCH AS TENDER DOCUMENTS AND

CHANGE NOTICES ARE TO BE ENDORSED BY LDB ASSOCIATES LIMITED

PRIOR TO THE BEGINNING OF ANY SITE WORKS. IN THE EVENT THAT OF A

IT IS THE RESPONSIBILITY OF THE PERSON OR PERSONS RESPONSIBLE FOR

THE CONSTRUCTED WORKS TO NOTIFY THE LANDSCAPE ARCHITECT WHEN

SCHEDULED MEETINGS SHALL TAKE PLACE AT THE CLOSEST MUTUALLY

ALL DRAWINGS AND SPECIFICATIONS ARE INSTRUMENTS OF SERVICE AND

ARE THE PROPERTY OF JDB ASSOCIATES LIMITED. DRAWINGS ARE NOT TO BE

ASSOCIATES LIMITED. REPRODUCTION OF DRAWINGS IN ANY FORM WITHOUT

THE CONSENT OF JDB ASSOCIATES LIMITED VOIDS THE DRAWING AT WHICH

TIME JDB ASSOCIATES LIMITED ACCEPTS NO LIABILITY FOR THE DRAWING

DRAWINGS MAY BE REPRODUCED BY MUNICIPAL AND GOVERNMEN'

JDB ASSOCIATES RESERVES THE RIGHT TO WITHDRAW ANY DRAWING(S) FROM GOVERNMENT OR MUNICIPAL AGENCIES WHETHER APPROVED OR NOT IN THE

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY ALL DIMENSIONS

ON THE SITE AND REPORT ANY DISCREPANCIES OR VARIATIONS FROM THE SUPPLIED INFORMATION TO THE LANDSCAPE ARCHITECT WITH THE PROJECT. JDB ASSOCIATES LIMITED IS NOT RESPONSIBLE FOR THE ACCURACY OF SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR ELECTRICAL INFORMATION SHOWN ON THE DRAWING. FOR FURTHER INFORMATION REFER TO APPROPRIATE SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR

BASE PLAN REVISED: MARCH. 2022

IPS- INNOVATIVE PLANNING

647 Welham Road, Unit 9A, Barrie, ON,

LANDSCAPE ARCHITECTS STAMP

Fax: 705-722-5660 Tel: 705-722-6278

Client info:

SOLUTIONS

L4N 0B7

CONTENT OR WORKS RESULTING FROM SAID REPRODUCTION

AGENCIES RESPONSIBLE FOR APPROVALS FOR THEIR OWN USE.

EVENT THAT ACCOUNTS ARE NOT SETTLED OR REMAIN OUTSTANDING

ELECTRICAL DRAWINGS PRIOR TO PROCEEDING WITH ANY WORKS.

THIS DRAWING IS NOT TO BE SCALED.

ACCEPTED BY

MODIFIED AND/OR REPRODUCED WITHOUT THE WRITTEN CONSENT OF JDB

DATE APRV

December 6th, 2022 StT

December 27th, 2023 StT

November 14th, 2024 StT

May 28th, 2024

August 1st, 2024

COMPANIES 48 HOURS PRIOR TO THE COMMENCEMENT OF ANY WORK.

DISCREPANCY THE DRAWING SHALL BE ASSUMED CORRECT.

PREPARED FOR ANY REQUIRED INSPECTIONS AND SIGN OFFS.

THE CONTRACTOR IS REQUIRED TO NOTIFY THE VARIOUS UTILITY

FLOODED ANNUAL/PERENNIAL MIXTURE AT A RATE OF 12kg PER

APPROXIMATELY 5,500 sq/m (+10%) (+/- MEASUREMENTS TO BE

2% NEW ENGLAND ASTER (Aster novae-anglaie)

12% BLACK EYED SUSAN (Rudbeckia hirta)

20% SAND DROPSEED (Sporobolus crytandrus

20% CANADA WILD RYE (Elymus candadensis)

4% CANADA GOLDEN ROD (Solidago canadensis

5% COMMON MILKWEED (Asclepias syriaca)

15% LITTLE BLUE STEM (Andropogon scoparius)

ANNUAL RYE NURSE CROP TO BE APPLIED AT TIME OF NATIVE

UPLAND PLANTING MIXTURE AT A RATE OF 12kg PER HECTARE.

REFER TO TERRASEEDING NOTES AND MULCH APPLICATION

ECOBLANKET OR TERRASEEDING TACTIFIER / FLEXGUARD

HYDROMULCH SHALL BE APPLIED AS PER MANUFACTURER

IN THE SWM POND AREA TOPSOIL SHALL BE PROVIDED TO A MINIMUM DEPTH OF 0.45m FOR TERRESTRIAL AREAS EXCEPT THE ACCESS ROAD BASE (5cm) AND MINIMUM 0.35m FOR

TOPSOIL OUALITY SHALL BE AS PER OPSS 570, IT SHALL BE

TESTED BY AN INDEPENDENT LABORATORY PRIOR TO

SPECIFICATIONS IN THIS BOX FOR FURTHER DETAILS.

TERRASEEDING APPLICATION SPECIFICATIONS

SPECIFICATIONS. SEE NOTES ON THIS PAGE.

TEMPORARY UNDERWATER AREAS.

1% WILD BERGAMONTE (Monarda Fistulosa

1% SMOOTH BLUE ASTER (Aster laevis)

20% INDIANGRASS (Sorghastrum nutans)

SUPPLIED BY - OSC SEEDS 1-519-886-0557

SITE CONDITIONS

VERIFY ALL EXISTING SITE CONDITIONS AND REPORT ANY DISCREPANCIES BEFORE COMMENCING WORK.

THE CONTRACTOR SHALL VERIFY THE LOCATION OF ALL UTILITIES AND IS RESPONSIBLE FOR ANY DAMAGE TO SERVICES, EXISTING VEGETATION OR ANY OTHER FEATURES TO BE RETAINED.

FOR ALL AREAS OF DISTURBANCE: NATIVE TOPSOIL IS TO BE STRIPPED, STOCK PILED, LABORATORY TESTED AND REPLACED AS PER TOPSOIL REOUIREMENTS.

PLANT MATERIAL REQUIREMENTS

PLANT MATERIAL LISTED IN THE PLANT SCHEDULE ARE MINIMUM SIZES +/- NURSERY GROWN AND UNIFORM SPECIMENS. NO SUBSTITUTIONS WILL BE PERMITTED WITHOUT WRITTEN APPROVAL FROM THE

DECIDUOUS TREES SHALL HAVE A STRAIGHT CENTRAL LEADER AND WELL BRANCHED 1.5M ABOVE GRADE UNLESS OTHERWISE STATED

CONIFEROUS TREES SHALL HAVE A STRAIGHT CENTRAL LEADER AND DENSELY BRANCHED TO WITHIN 0.3m

ALL PLANTING MATERIAL AND OPERATIONS TO MEET OR EXCEED THE HORTICULTURAL STANDARDS OF THE CANADIAN NURSERY LANDSCAPE ASSOCIATION AND THE HORTICULTURAL TRADES ASSOCIATION. ALL PLANT MATERIAL TO BE NO.1 GRADE NURSERY STOCK. UNSATISFACTORY STOCK WILL BE REFUSED ON THE

SOD TO BE CANADA NO.1 NURSERY SOD, MEETING ONTARIO SOD GROWERS ASSOCIATION STANDARDS. ALL SOD AREAS TO RECEIVE 200MM DEPTH OF TOPSOIL UNLESS OTHERWISE INDICATED.

PLANTING NOTES

LOCATIONS FOR PLANT MATERIAL AND PLANTING BEDS ARE TO BE MARKED OR STAKED OUT BY THE CONTRACTOR AND APPROVED BY THE LANDSCAPE ARCHITECT AND MUNICIPAL STAFF PRIOR TO

. ALL PLANT MATERIAL WHICH ARE SPECIFIED BY O.C. (ON CENTER SPACING) ARE TO BE PLANTED AS NOTED IN THE PLANT SCHEDULE

. IN THE EVENT OF A DISCREPANCY BETWEEN THE PLANT LIST AND DRAWING, THE DRAWING WILL BE ASSUMED TO BE CORRECT.

ALL MASS PLANTINGS OF SHRUBS SHALL BE IN CONTINUOUS BEDS AND MULCHED AS SPECIFIED.

ALL TREE PITS SHALL INCLUDE TREATMENT WITH MICORRHIZAL FUNGLOF THE WALLS BEFORE PLANTING

(2L OF "MIKE" OR SIMILAR PRODUCT SHALL BE USED FOR EACH 60MM CALIPER TREE) ALL TREES ARE TO BE STAKED OR GUY WIRED ACCORDING TO DETAILS PROVIDED. NO ACCESSIBLE OPEN

HOLE TREE PITS SHALL BE PERMITTED OVERNIGHT.

. REMOVE BURLAP AND ROPE FROM THE TOP 1/3 OF ROOT BALLS.

. WATER AT TIME OF PLANTING AND WHENEVER DEEMED NECESSARY TO MAINTAIN THE TREES IN A

ALL PLANT MATERIALS WHICH CAN NOT BE PLANTED IMMEDIATELY UPON ARRIVAL ON SITE SHALL BE PROPERLY HEELED IN OR WELL PROTECTED WITH SOIL OR SIMILAR MATERIALS TO PREVENT DRYING OUT AND SHALL BE KEPT MOIST UNTIL COMMENCEMENT OF PLANTING

NO ACCESSIBLE OPEN HOLE TREE PITS SHALL BE PERMITTED OVERNIGHT. ALL OPEN PITS SHALL BE ADEQUATELY PROTECTED BY BARRIERS OR FILLED IN WITH SOIL PRIOR TO THE END OF EACH PLANTING

PLANTING NOTES (REFER TO "SEEDING AND TOPSOIL NOTES" ON THIS PAGE FOR THE SWM POND AREA)

9. ALL NEW WORK TO BLEND NEATLY AND SMOOTHLY WITH EXISTING CONDITIONS.

INSPECTION AND WARRANTY

1. GIVE TIMELY NOTICE TO THE LANDSCAPE ARCHITECT FOR THE REQUIRED START UP SITE INSPECTION TO REVIEW SITE CONDITIONS AND SCHEDULE FOLLOW UP INSTALLATIONS

2. INSTALLATION OF PLANT MATERIAL PRIOR TO INSPECTION BY THE LANDSCAPE ARCHITECT WILL BE THE CONTRACTOR'S RESPONSIBILITY.

3. THE LANDSCAPE ARCHITECT RESERVES THE RIGHT TO REJECT ANY PLANTS, WHETHER INSTALLED OR NOT, WHICH DO NOT CONFORM TO THE SPECIFICATIONS AND/OR SITE DRAWING. REMOVE ALL REJECTED PLANTS FROM THE SITE IMMEDIATELY. DO NOT REMOVE ANY LABELS FROM PLANTS UNTIL PLANTS HAVE BEEN INSPECTED AND APPROVED BY THE LANDSCAPE ARCHITECT

4. ALL PLANT MATERIAL AND WORKMANSHIP WILL BE INSPECTED AND IS UNDER WARRANTY FOR A MINIMUM OF TWO YEAR FROM DATE OF WRITTEN ACCEPTANCE. ALL PLANT MATERIAL MUST BE IN A HEALTHY, VIGOROUS GROWING CONDITION SATISFACTORY TO THE CONTRACT ADMINISTRATOR AT THE END OF THE WARRANTY PERIOD OR BE REPLACED AT THE CONTRACTORS EXPENSE.

5. FINAL ACCEPTANCE OF THE PROJECT WILL BE CARRIED OUT UPON COMPLETION OF ALL WORK INCLUDED IN THE CONTRACT.

TOPSOIL REQUIREMENTS (LANDSCAPING AREAS)

WEED SEEDS AND GRASS ROOTS

6. PROVIDE MINIMUM SOIL VOLUME PER TREE AT 0.45m DEPTH FOR STREET TREES (OR ABOVE UTILITIES) AND MAX. 0.9m IN OTHER


- 18 m³ FOR LARGE TREES - 12 m³ FOR SMALL TREES

7. PREPARED SOIL MIXTURE FOR EACH TREE PITS AND SHRUBS SHALL CONSIST OF HIGH OUALITY SOIL SIX PARTS OF FERTILE LOAM SOIL (50-60% SAND, 20-40% SILT, 6-10% CLAY, 2-5% ORGANIC), WITH A pH OF 7.5* OR LESS, FREE OF CLAY

LUMPS, DEBRIS, TOXIC SUBSTANCES, STONES, WOODY MATERIAL,

WEED SEEDS AND GRASS ROOTS ONE PART COARSE PULVERIZED CANADIAN PEAT MOSS ONE PART OF WELL-ROTTED FARM MANURE

8. PREPARED SOIL MIXTURE FOR SOD AREAS SHALL CONSIST OF MIN. 20cm HIGH QUALITY SOIL: SIX PARTS OF FERTILE LOAM SOIL (50-60% SAND, 20-40% SILT, 6-10% CLAY, 2-5% ORGANIC), WITH A pH OF 7.5* OR LESS, FREE OF CLAY LUMPS, DEBRIS, TOXIC SUBSTANCES, STONES, WOODY MATERIAL,



This work shall consist of furnishing, constructing and maintaining an EcoBlanket(to Rexius specifications. EcoBlanket is a ground cover (surface blanket) of the Rexius specified compost/mulch (Erosion Blend) combined with a special additive (Microblend) constructed with a pneumatic blower to control and reduce soil erosion. An EcoBlanket stabilizes the soil, prevents splash, sheet and rill erosion, and removes suspended soil particles and contaminants from water moving off the site and into adjacent waterways or

equivalent certified EcoBlanket installer 1.2. Materials must be applied using a pneumatic blower unit complete with a supplemental granular injection system capable of installing at least 15 cubic meters per hour.

1.3. Contractor must have at least 3 years of proven experience in successfully installing EcoBlanketsTM.

The EcoBlanket filtering material consists of the Rexius Erosion Blend of compost and mulch materials, according to the Rexius particle sizing specifications, in combination with the Rexius Microblend additive.

2.2. The compost portion of EcoBlanket shall be derived from well-decomposed organic matter source produced by controlled aerobic (biological) decomposition that has been sanitized through the generation of heat and stabilized to the point that it is appropriate for this particular application. Compost material shall be processed through proper thermophilic composting, meeting the Canadian Council of Ministers of the Environment's (CCME) definition for a 'process to further reduce pathogens' (PFRP). The compost portion shall meet the chemical, physical and biological properties (as outlined in the chart on reverse). These and all other required properties for the performance of the EcoBlanket are included in the Rexius EcoBlanket Manufacture Guidelines followed by certified suppliers/installers. 2.3. Rexius Microblend additive shall be injected into Erosion Blend material at time of EcoBlanket construction.

shall be made available upon request.

3.2. On areas with slopes 3:1 to 2:1 (H:V) the EcoBlanket shall be uniformly applied directly at the soil surface with a pneumatic blower as specified by Rexius. EcoBlanket shall be applied at a depth of 50 mm minimum and approximately 90 cm over the top of the slope, or overlap it into existing vegetation. On areas with slopes up to 3:1(H:V) the EcoBlanket shall be applied at a depth of 25mm minimum. In extreme conditions and where specified by the Engineer/Landscape Architect., EcoBerms shall be added and

3.3. Rexius Microblend shall be applied/injected at a minimum rate of 615 kgs. per hectare (or as specified by Rexius), to be confirmed by inspector/project manager. 3.4. EcoBlanket application depth may be modified based on specific site (e.g., soil characteristics, existing vegetation) and climatic conditions, as well as particular project related requirements. The severity of slope grade, as well as slope length will also influence the addition of EcoBerms and number of EcoBerm placements in combination with

3.5. If temporary or long-term vegetation is required, Erosion Blend material may be injected with seed during application. The Engineer/Landscape Architect shall specify seed requirements and the compost/mulch component shall abide by the minimum standards set by Rexius for seeding 3.6. Where vegetation is to be established, slightly roughen (scarify) slopes and remove large clods, rocks, stumps, roots larger than 50 mm in diameter and debris on slopes. This soil preparation step may be eliminated where approved by the Landscape Architect/Designer, or where seeding or planting is not planned. Where practical, track (compact) perpendicular to contours on the slope using a bulldozer before applying EcoBlanket injected with seed.

The Contractor shall maintain the EcoBlanket in a functional condition at all times. Contractor shall make periodic inspections of the EcoBlanket for effectiveness and shall immediately correct all deficiencies. Where deficiencies exist, additional EcoBlanket material shall be installed immediately to required depth.

when necessary, along with other appropriate structural measures and controls, for additional erosion and sediment control. 6.2. The work specified in this Section consists of designing, providing, and maintaining erosion and sedimentation controls as necessary. All existing and foreseeable future

Soluble Salt Concentration2 (electrical conductivity) ds/m (mmhos/cm) Maximum 5 N/A Stability3 Carbon Dioxide Evolution Rate mg CO2-C per g OM per day < 8 N/A

1. Recommended test methodologies are provided in Test Methods for the Examination of Composting and Compost (SCC through BNQ) 2. Each specific plant species requires a specific pH range. Each plant also has a salinity tolerance rating, and maximum tolerable quantities are known. When specifying the establishment of any plant or turf species, it is important to understand their pH and soluble salt requirements, and how they relate to the compost in use. 3. Stability/Maturity rating is an area of compost science that is still evolving, and as such, other various test methodscould be considered. Also, never base compost quality conclusions on the result of a single stability/maturity test.

4. Landscape Architect may modify the allowable compost specification ranges based on specific field conditions and plant requirements.

JDB associates LTD.

274 Burton Ave., Suite 1201

Urban Designers

Barrie, Ontario

Arborists

L4N 5W4

Landscape Architects

LANDSCAPE PLAN DETAILS

REVIEWED BY: NTS TOWN FILE No. OUR FILE REF. # LP-2

LOT 31 CLARK ST


Town of the Blue Mountains, ON

storm water conveyance systems 1.1. This EcoBlanket must be applied by Landsource Organix Ltd., 100 Britannia Road East, Hornby, Ontario L0P 1E0, tollfree 1 877 548 8558 (toll free fax 1 877 548 8559) or 2.1. Particle size must meet exact specifications of the Rexius EcoBlanket Erosion Blend material supplied by a certified supplier/installer 2.4. A proof of certification as an EcoBlanket supplier shall be submitted to the Landscape Architect for approval prior to installation. Test results for EcoBlanket performance 2.5. Where seeding or planting is planned, Erosion Blend material must meet Rexius' minimum specification requirements for seeding purposes. 1. The EcoBlanket shall be placed as shown on the plans or as directed by the Landscape Architect. constructed at the top of the slope in parallel intervals down the profile of the slope (6 metres to 9 metres apart) if necessary. (The Engineer/Landscape Architect shall specify 3.7. Do not use EcoBlankets in areas of concentrated flow (ie. ditches, streams, etc.) 3.8. Unless otherwise allowed by Landscape Architect, seeding shall be performed within the local region's seeding deadlines. 5.0 Method of Measurement: EcoBlanket shall be measured by the square metre, complete in place. 6.1. Place EcoBlankets on denuded areas immediately or as directed by Landscape Architect. EcoBerms and/or temporary or permanent vegetation shall be applied/established conditions that affect the work inside and outside the site limits must be acknowledged as the Contractor's responsibility. 6.3. Contractor is responsible for providing effective sediment control measures based on performance. Contractor may, with approval from the Landscape Architect, work outside the minimum construction requirements to establish a working erosion control system. Parameters 1,4 Reported as (units of measure) EcoBlanket to be Vegetated EcoBlanket to be left Un-vegetated PH2 pH units 5.0 - 8.5 N/A

Physical Contaminants (man-made inerts) % dry weight basis < 1 < 1

ECOBLANKET SPECIFICATIONS AND DETAIL

DETAIL ADAPTED FROM LANDSOURCE ORGANIX EcoBlanket (tel.:1-877-548-8558)




SECURITY CHAIN LINK FENCE DETAIL - black vinyl coated

ADA Hex Recycled Plastic Picnic Table - 46", Cedar


Virtually maintenance free! Recommended for warehouse patios, campgrounds, schools and parks. · Accommodates 1 wheelchair and 4 adults.

- 100% recycled UV-protected plastic won't rot, splinter or crack. Withstands harsh weather.
- Natural-looking wood material never needs sanding, sealing, painting or staining.
- · Durable 2" thick planks predrilled for easy assembly.
- H-6681 Mounting Hardware available.


PICNIC BENCH U-LINE MODEL H-6575 ON CONCRETE PAD (BELOW)



CONCRETE PAD DETAIL (typ.)



GARBAGE ENCLOSURE FENCE DETAIL



GATE DETAIL (typ.) - GATE STYLE TO MATCH THE FENCE STYLE AND SPECS.

SHOP DRAWING TO BE PROVIDED TO THE LANDSCAPE ARCHITECT FOR APPROVAL BEFORE CONSTRUCTION



GENERAL NOTES

CONTRACTOR IS RESPONSIBLE FOR ALL LOCATES INCLUDING ALL UNDERGROUND SERVICES PRIOR TO ANY EXCAVATION OR INSTALLATIONS. THE CONTRACTOR IS REQUIRED TO NOTIFY THE VARIOUS UTILITY COMPANIES 48 HOURS PRIOR TO THE COMMENCEMENT OF ANY WORK.

ANY ACCOMPANYING DOCUMENTATION RELATING TO THE LANDSCAPE PLAN AND/OR PRESERVATION PLAN SUCH AS TENDER DOCUMENTS AND CHANGE NOTICES ARE TO BE ENDORSED BY J.D.B. ASSOCIATES LIMITED PRIOR TO THE BEGINNING OF ANY SITE WORKS. IN THE EVENT THAT OF A DISCREPANCY THE DRAWING SHALL BE ASSUMED CORRECT.

IT IS THE RESPONSIBILITY OF THE PERSON OR PERSONS RESPONSIBLE FOR THE CONSTRUCTED WORKS TO NOTIFY THE LANDSCAPE ARCHITECT WHEN PREPARED FOR ANY REQUIRED INSPECTIONS AND SIGN OFFS.

SCHEDULED MEETINGS SHALL TAKE PLACE AT THE CLOSEST MUTUALLY CONVENIENT TIME.

No.	REVISION	DATE	APRVD
1.	CLIENT REVIEW	December 6 th , 2022	StT
2.	AS PER TOWN COMMENTS	December 27 th , 2023	StT
3.	AS PER TOWN COMMENTS	May 28 th , 2024	StT
4.	AS PER TOWN COMMENTS	August 1st, 2024	StT
5.	AS PER UPDATED SITE PLAN	November 14 th , 2024	StT

ALL DRAWINGS AND SPECIFICATIONS ARE INSTRUMENTS OF SERVICE AND ARE THE PROPERTY OF JDB ASSOCIATES LIMITED. DRAWINGS ARE NOT TO BE MODIFIED AND/OR REPRODUCED WITHOUT THE WRITTEN CONSENT OF JDB ASSOCIATES LIMITED REPRODUCTION OF DRAWINGS IN ANY FORM WITHOUT THE CONSENT OF JDB ASSOCIATES LIMITED VOIDS THE DRAWING AT WHICH TIME JDB ASSOCIATES LIMITED ACCEPTS NO LIABILITY FOR THE DRAWING CONTENT OR WORKS RESULTING FROM SAID REPRODUCTION. DRAWINGS MAY BE REPRODUCED BY MUNICIPAL AND GOVERNMENT AGENCIES RESPONSIBLE FOR APPROVALS FOR THEIR OWN USE. JDB ASSOCIATES RESERVES THE RIGHT TO WITHDRAW ANY DRAWING(S) FROM GOVERNMENT OR MUNICIPAL AGENCIES WHETHER APPROVED OR NOT IN THE EVENT THAT ACCOUNTS ARE NOT SETTLED OR REMAIN OUTSTANDING

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY ALL DIMENSIONS ON THE SITE AND REPORT ANY DISCREPANCIES OR VARIATIONS FROM THE SUPPLIED INFORMATION TO THE LANDSCAPE ARCHITECT WITH THE PROJECT. JDB ASSOCIATES LIMITED IS NOT RESPONSIBLE FOR THE ACCURACY OF SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR ELECTRICAL INFORMATION SHOWN ON THE DRAWING. FOR FURTHER INFORMATION REFER TO APPROPRIATE SURVEY, ARCHITECTURAL, MECHANICAL, ENGINEERING OR ELECTRICAL DRAWINGS PRIOR TO PROCEEDING WITH ANY WORKS.

THIS DRAWING IS NOT TO BE SCALED.




ACCEPTED BY:



JDB associates LTD.

Urban Designers Landscape Architects

274 Burton Ave., Suite 1201 Barrie, Ontario L4N 5W4



LOT 31 CLARK ST Town of the Blue Mountains, ON

LANDSCAPE/ RESTORATION PLANTING PLAN

SCALE:	DESIGNED BY:	REVIEWED BY:		
1:600	IT	NB		
TOWN FILE No.	OUR FILE REF. # 14-22	LP-3		

Appendix E – Sediment Removal Calculations

Figure 6.3: Storage Volume vs. Removal Frequency – for 70% Impervious Catchments





Figure 6.4: Storage Volume vs. Removal Frequency – for 85% Impervious Catchments



Assumed 70% Removal Efficiency (modified dry pond)

Appendix F – OGS Information



CDS ESTIMATED NET ANNUAL SOLIDS LOAD REDUCTION BASED ON THE RATIONAL RAINFALL METHOD **BASED ON A FINE PARTICLE SIZE DISTRIBUTION**



Project Name: 185 Clark Street **Engineer: Capes Engineering** Location: Blue Mountains, ON Contact: Clayton Capes, P.Eng

OGS #: Report Date: 15-Aug-22

Area 0.920 ha Rainfall Station # 198 Weighted C **Particle Size Distribution** 0.90 **FINE CDS Model** 2025 **CDS Treatment Capacity** 45 l/s

Rainfall Intensity ¹ (mm/hr)	Percent Rainfall Volume ¹	Cumulative Rainfall Volume	Total Flowrate (I/s)	<u>Treated</u> <u>Flowrate (I/s)</u>	Operating Rate (%)	Removal Efficiency (%)	Incremental Removal (%)
1.0	10.8%	21.1%	2.3	2.3	5.1	97.4	10.5
1.5	10.1%	31.2%	3.5	3.5	7.6	96.7	9.7
2.0	8.5%	39.7%	4.6	4.6	10.2	95.9	8.1
2.5	6.7%	46.4%	5.8	5.8	12.7	95.2	6.4
3.0	6.1%	52.4%	6.9	6.9	15.2	94.5	5.7
3.5	4.1%	56.5%	8.1	8.1	17.8	93.8	3.8
4.0	4.2%	60.7%	9.2	9.2	20.3	93.0	3.9
4.5	3.7%	64.4%	10.4	10.4	22.9	92.3	3.4
5.0	3.9%	68.2%	11.5	11.5	25.4	91.6	3.5
6.0	5.3%	73.5%	13.8	13.8	30.5	90.1	4.8
7.0	3.8%	77.4%	16.1	16.1	35.6	88.7	3.4
8.0	2.8%	80.1%	18.4	18.4	40.6	87.2	2.4
9.0	2.5%	82.6%	20.7	20.7	45.7	85.8	2.1
10.0	2.1%	84.7%	23.0	23.0	50.8	84.3	1.8
15.0	5.7%	90.5%	34.5	34.5	76.2	77.0	4.4
20.0	3.4%	93.8%	46.0	45.3	100.0	69.1	2.3
25.0	3.4%	97.2%	57.5	45.3	100.0	55.3	1.9
30.0	0.8%	98.0%	69.1	45.3	100.0	46.1	0.4
35.0	0.9%	98.8%	80.6	45.3	100.0	39.5	0.3
40.0	0.4%	99.3%	92.1	45.3	100.0	34.5	0.1
45.0	0.5%	99.7%	103.6	45.3	100.0	30.7	0.1
50.0	0.3%	100.0%	115.1	45.3	100.0	27.6	0.1
							89.4

Removal Efficiency Adjustment² =

6.5%


Predicted Net Annual Load Removal Efficiency = 82.9%

Predicted Annual Rainfall Treated =

96.9%

- 1 Based on 38 years of hourly rainfall data from Canadian Station 6166132, Owen Sound ON
- 2 Reduction due to use of 60-minute data for a site that has a time of concentration less than 30-minutes.
- 3 CDS Efficiency based on testing conducted at the University of Central Florida
- 4 CDS design flowrate and scaling based on standard manufacturer model & product specifications

PLAN VIEW B-B





CDS PMSU2025-5-C DESIGN NOTES

THE STANDARD CDS PMSU2025-5-C CONFIGURATION IS SHOWN. ALTERNATE CONFIGURATIONS ARE AVAILABLE AND ARE LISTED BELOW. SOME CONFIGURATIONS MAY BE COMBINED TO SUIT SITE REQUIREMENTS.

CONFIGURATION DESCRIPTION

GRATED INLET ONLY (NO INLET PIPE)


GRATED INLET WITH INLET PIPE OR PIPES

CURB INLET ONLY (NO INLET PIPE)

CURB INLET WITH INLET PIPE OR PIPES

CUSTOMIZABLE SUMP DEPTH AVAILABLE

ANTI-FLOTATION DESIGN AVAILABLE UPON REQUEST



FRAME AND COVER (DIAMETER VARIES) N.T.S.

SITE SPECIFIC DATA REQUIREMENTS							
STRUCTURE ID							
WATER QUALITY	FLOW RAT	Ε(CFS OR L/s)		*		
PEAK FLOW RAT	E (CFS OR	L/s)			*		
RETURN PERIOD	OF PEAK F	LO	W (YRS)		*		
SCREEN APERTU	JRE (2400 C	R 4	1700)		*		
PIPE DATA:	I.E.		MATERIAL	D	IAMETER		
INLET PIPE 1	*	H.	*		*		
INLET PIPE 2	*		*		*		
OUTLET PIPE	*		*		*		
RIM ELEVATION					*		
ANTI-FLOTATION	BALLAST		WIDTH *	Ŧ	HEIGHT *		
NOTES/SPECIAL REQUIREMENTS:							
* PER ENGINEER OF RECORD							

GENERAL NOTES

- 1. CONTECH TO PROVIDE ALL MATERIALS UNLESS NOTED OTHERWISE.
- 2. DIMENSIONS MARKED WITH () ARE REFERENCE DIMENSIONS. ACTUAL DIMENSIONS MAY VARY.
- 3. FOR FABRICATION DRAWINGS WITH DETAILED STRUCTURE DIMENSIONS AND WEIGHTS, PLEASE CONTACT YOUR CONTECH ENGINEERED SOLUTIONS LLC REPRESENTATIVE. www.contechES.com
- 4. CDS WATER QUALITY STRUCTURE SHALL BE IN ACCORDANCE WITH ALL DESIGN DATA AND INFORMATION CONTAINED IN THIS DRAWING.
- 5. STRUCTURE SHALL MEET AASHTO HS20 AND CASTINGS SHALL MEET HS20 (AASHTO M 306) LOAD RATING, ASSUMING GROUNDWATER ELEVATION AT, OR BELOW, THE OUTLET PIPE INVERT ELEVATION. ENGINEER OF RECORD TO CONFIRM ACTUAL GROUNDWATER ELEVATION.
- 6. PVC HYDRAULIC SHEAR PLATE IS PLACED ON SHELF AT BOTTOM OF SCREEN CYLINDER. REMOVE AND REPLACE AS NECESSARY DURING MAINTENANCE CLEANING.

INSTALLATION NOTES

- A. ANY SUB-BASE, BACKFILL DEPTH, AND/OR ANTI-FLOTATION PROVISIONS ARE SITE-SPECIFIC DESIGN CONSIDERATIONS AND SHALL BE SPECIFIED BY ENGINEER OF RECORD.
- B. CONTRACTOR TO PROVIDE EQUIPMENT WITH SUFFICIENT LIFTING AND REACH CAPACITY TO LIFT AND SET THE CDS MANHOLE STRUCTURE (LIFTING CLUTCHES PROVIDED).
- C. CONTRACTOR TO ADD JOINT SEALANT BETWEEN ALL STRUCTURE SECTIONS, AND ASSEMBLE STRUCTURE.
- D. CONTRACTOR TO PROVIDE, INSTALL, AND GROUT PIPES. MATCH PIPE INVERTS WITH ELEVATIONS SHOWN.
- E. CONTRACTOR TO TAKE APPROPRIATE MEASURES TO ASSURE UNIT IS WATER TIGHT, HOLDING WATER TO FLOWLINE INVERT MINIMUM. IT IS SUGGESTED THAT ALL JOINTS BELOW PIPE INVERTS ARE GROUTED.



800-338-1122 513-645-7000 513-645-7993 FAX

CDS PMSU2025-5-C INLINE CDS STANDARD DETAIL



CDS ESTIMATED NET ANNUAL SOLIDS LOAD REDUCTION BASED ON THE RATIONAL RAINFALL METHOD BASED ON A FINE PARTICLE SIZE DISTRIBUTION



Project Name:185 Clark StreetEngineer:Capes EngineeringLocation:Blue Mountains, ONContact:Clayton Capes, P.Eng

OGS #: 2 Report Date: 15-Aug-22

Area0.360haRainfall Station #198Weighted C0.90Particle Size DistributionFINECDS Model2015CDS Treatment Capacity20I/s

Rainfall Intensity ¹ (mm/hr)	Percent Rainfall Volume ¹	Cumulative Rainfall Volume	Total Flowrate (I/s)	Treated Flowrate (I/s)	Operating Rate (%)	Removal Efficiency (%)	Incremental Removal (%)
1.0	10.8%	21.1%	0.9	0.9	4.5	97.6	10.5
1.5	10.1%	31.2%	1.4	1.4	6.8	96.9	9.8
2.0	8.5%	39.7%	1.8	1.8	9.1	96.3	8.2
2.5	6.7%	46.4%	2.3	2.3	11.4	95.6	6.4
3.0	6.1%	52.4%	2.7	2.7	13.6	94.9	5.7
3.5	4.1%	56.5%	3.2	3.2	15.9	94.3	3.9
4.0	4.2%	60.7%	3.6	3.6	18.2	93.6	3.9
4.5	3.7%	64.4%	4.1	4.1	20.4	93.0	3.4
5.0	3.9%	68.2%	4.5	4.5	22.7	92.3	3.6
6.0	5.3%	73.5%	5.4	5.4	27.3	91.0	4.8
7.0	3.8%	77.4%	6.3	6.3	31.8	89.7	3.4
8.0	2.8%	80.1%	7.2	7.2	36.3	88.4	2.4
9.0	2.5%	82.6%	8.1	8.1	40.9	87.1	2.2
10.0	2.1%	84.7%	9.0	9.0	45.4	85.8	1.8
15.0	5.7%	90.5%	13.5	13.5	68.2	79.3	4.5
20.0	3.4%	93.8%	18.0	18.0	90.9	72.8	2.5
25.0	3.4%	97.2%	22.5	19.8	100.0	61.8	2.1
30.0	0.8%	98.0%	27.0	19.8	100.0	51.5	0.4
35.0	0.9%	98.8%	31.5	19.8	100.0	44.1	0.4
40.0	0.4%	99.3%	36.0	19.8	100.0	38.6	0.2
45.0	0.5%	99.7%	40.5	19.8	100.0	34.3	0.2
50.0	0.3%	100.0%	45.0	19.8	100.0	30.9	0.1
				·	·		90.5

Removal Efficiency Adjustment² =


6.5%

Predicted Net Annual Load Removal Efficiency = Predicted Annual Rainfall Treated =

84.0% 97.4%

- 1 Based on 38 years of hourly rainfall data from Canadian Station 6166132, Owen Sound ON
- 2 Reduction due to use of 60-minute data for a site that has a time of concentration less than 30-minutes.
- 3 CDS Efficiency based on testing conducted at the University of Central Florida
- 4 CDS design flowrate and scaling based on standard manufacturer model & product specifications

PLAN VIEW B-B





CDS PMSU2015-4-C DESIGN NOTES

THE STANDARD CDS PMSU2015-4-C CONFIGURATION IS SHOWN. ALTERNATE CONFIGURATIONS ARE AVAILABLE AND ARE LISTED BELOW. SOME CONFIGURATIONS MAY BE COMBINED TO SUIT SITE REQUIREMENTS.

CONFIGURATION DESCRIPTION

GRATED INLET ONLY (NO INLET PIPE)


GRATED INLET WITH INLET PIPE OR PIPES

CURB INLET ONLY (NO INLET PIPE)

CURB INLET WITH INLET PIPE OR PIPES

CUSTOMIZABLE SUMP DEPTH AVAILABLE

ANTI-FLOTATION DESIGN AVAILABLE UPON REQUEST



FRAME AND COVER (DIAMETER VARIES) N.T.S.

SITE SPECIFIC DATA REQUIREMENTS							
					<u> </u>		
STRUCTURE ID							
WATER QUALITY	FLOW RAT	E (CF	S OR L/s)		*		
PEAK FLOW RAT	E (CFS OR	L/s)			*		
RETURN PERIOD	OF PEAK F	LOW	(YRS)		*		
SCREEN APERTU	JRE (2400 C	R 470	00)		*		
PIPE DATA:	I.E.	MA	TERIAL	D	IAMETER		
INLET PIPE 1	*		*		*		
INLET PIPE 2	*		*		*		
OUTLET PIPE	*		*		*		
RIM ELEVATION					*		
ANTI-FLOTATION	BALLAST		WIDTH		HEIGHT		
			*		*		
NOTES/SPECIAL	REQUIREM	ENTS	:	•			
* PER ENGINEER OF RECORD							

GENERAL NOTES

- 1. CONTECH TO PROVIDE ALL MATERIALS UNLESS NOTED OTHERWISE.
- 2. DIMENSIONS MARKED WITH () ARE REFERENCE DIMENSIONS. ACTUAL DIMENSIONS MAY VARY.
- 3. FOR FABRICATION DRAWINGS WITH DETAILED STRUCTURE DIMENSIONS AND WEIGHTS, PLEASE CONTACT YOUR CONTECH ENGINEERED SOLUTIONS LLC REPRESENTATIVE. www.contechES.com
- 4. CDS WATER QUALITY STRUCTURE SHALL BE IN ACCORDANCE WITH ALL DESIGN DATA AND INFORMATION CONTAINED IN THIS DRAWING.
- 5. STRUCTURE SHALL MEET AASHTO HS20 AND CASTINGS SHALL MEET HS20 (AASHTO M 306) LOAD RATING, ASSUMING GROUNDWATER ELEVATION AT, OR BELOW, THE OUTLET PIPE INVERT ELEVATION. ENGINEER OF RECORD TO CONFIRM ACTUAL GROUNDWATER ELEVATION.
- 6. PVC HYDRAULIC SHEAR PLATE IS PLACED ON SHELF AT BOTTOM OF SCREEN CYLINDER. REMOVE AND REPLACE AS NECESSARY DURING MAINTENANCE CLEANING.

INSTALLATION NOTES

- A. ANY SUB-BASE, BACKFILL DEPTH, AND/OR ANTI-FLOTATION PROVISIONS ARE SITE-SPECIFIC DESIGN CONSIDERATIONS AND SHALL BE SPECIFIED BY ENGINEER OF RECORD.
- 3. CONTRACTOR TO PROVIDE EQUIPMENT WITH SUFFICIENT LIFTING AND REACH CAPACITY TO LIFT AND SET THE CDS MANHOLE STRUCTURE (LIFTING CLUTCHES PROVIDED).
- C. CONTRACTOR TO ADD JOINT SEALANT BETWEEN ALL STRUCTURE SECTIONS, AND ASSEMBLE STRUCTURE.
- D. CONTRACTOR TO PROVIDE, INSTALL, AND GROUT PIPES. MATCH PIPE INVERTS WITH ELEVATIONS SHOWN.
- E. CONTRACTOR TO TAKE APPROPRIATE MEASURES TO ASSURE UNIT IS WATER TIGHT, HOLDING WATER TO FLOWLINE INVERT MINIMUM. IT IS SUGGESTED THAT ALL JOINTS BELOW PIPE INVERTS ARE GROUTED.



CDS PMSU2015-4-C INLINE CDS STANDARD DETAIL



CDS® Inspection and Maintenance Guide





Maintenance

The CDS system should be inspected at regular intervals and maintained when necessary to ensure optimum performance. The rate at which the system collects pollutants will depend more heavily on site activities than the size of the unit. For example, unstable soils or heavy winter sanding will cause the grit chamber to fill more quickly but regular sweeping of paved surfaces will slow accumulation.

Inspection

Inspection is the key to effective maintenance and is easily performed. Pollutant transport and deposition may vary from year to year and regular inspections will help ensure that the system is cleaned out at the appropriate time. At a minimum, inspections should be performed twice per year (e.g. spring and fall) however more frequent inspections may be necessary in climates where winter sanding operations may lead to rapid accumulations, or in equipment washdown areas. Installations should also be inspected more frequently where excessive amounts of trash are expected.

The visual inspection should ascertain that the system components are in working order and that there are no blockages or obstructions in the inlet and separation screen. The inspection should also quantify the accumulation of hydrocarbons, trash, and sediment in the system. Measuring pollutant accumulation can be done with a calibrated dipstick, tape measure or other measuring instrument. If absorbent material is used for enhanced removal of hydrocarbons, the level of discoloration of the sorbent material should also be identified during inspection. It is useful and often required as part of an operating permit to keep a record of each inspection. A simple form for doing so is provided.

Access to the CDS unit is typically achieved through two manhole access covers. One opening allows for inspection and cleanout of the separation chamber (cylinder and screen) and isolated sump. The other allows for inspection and cleanout of sediment captured and retained outside the screen. For deep units, a single manhole access point would allows both sump cleanout and access outside the screen.

The CDS system should be cleaned when the level of sediment has reached 75% of capacity in the isolated sump or when an appreciable level of hydrocarbons and trash has accumulated. If absorbent material is used, it should be replaced when significant discoloration has occurred. Performance will not be impacted until 100% of the sump capacity is exceeded however it is recommended that the system be cleaned prior to that for easier removal of sediment. The level of sediment is easily determined by measuring from finished grade down to the top of the sediment pile. To avoid underestimating the level of sediment in the chamber, the measuring device must be lowered to the top of the sediment pile carefully. Particles at the top of the pile typically offer less resistance to the end of the rod than consolidated particles toward the bottom of the pile. Once this measurement is recorded, it should be compared to the as-built drawing for the unit to determine weather the height of the sediment pile off the bottom of the sump floor exceeds 75% of the total height of isolated sump.

Cleaning

Cleaning of a CDS systems should be done during dry weather conditions when no flow is entering the system. The use of a vacuum truck is generally the most effective and convenient method of removing pollutants from the system. Simply remove the manhole covers and insert the vacuum hose into the sump. The system should be completely drained down and the sump fully evacuated of sediment. The area outside the screen should also be cleaned out if pollutant build-up exists in this area.

In installations where the risk of petroleum spills is small, liquid contaminants may not accumulate as quickly as sediment. However, the system should be cleaned out immediately in the event of an oil or gasoline spill should be cleaned out immediately. Motor oil and other hydrocarbons that accumulate on a more routine basis should be removed when an appreciable layer has been captured. To remove these pollutants, it may be preferable to use absorbent pads since they are usually less expensive to dispose than the oil/water emulsion that may be created by vacuuming the oily layer. Trash and debris can be netted out to separate it from the other pollutants. The screen should be power washed to ensure it is free of trash and debris.

Manhole covers should be securely seated following cleaning activities to prevent leakage of runoff into the system from above and also to ensure that proper safety precautions have been followed. Confined space entry procedures need to be followed if physical access is required. Disposal of all material removed from the CDS system should be done in accordance with local regulations. In many jurisdictions, disposal of the sediments may be handled in the same manner as the disposal of sediments removed from catch basins or deep sump manholes.



CDS Model	Diameter		Distance from Water Surface to Top of Sediment Pile		Sediment Storage Capacity	
	ft	m	ft	m	y³	m³
CDS1515	3	0.9	3.0	0.9	0.5	0.4
CDS2015	4	1.2	3.0	0.9	0.9	0.7
CDS2015	5	1.3	3.0	0.9	1.3	1.0
CDS2020	5	1.3	3.5	1.1	1.3	1.0
CDS2025	5	1.3	4.0	1.2	1.3	1.0
CDS3020	6	1.8	4.0	1.2	2.1	1.6
CDS3025	6	1.8	4.0	1.2	2.1	1.6
CDS3030	6	1.8	4.6	1.4	2.1	1.6
CDS3035	6	1.8	5.0	1.5	2.1	1.6
CDS4030	8	2.4	4.6	1.4	5.6	4.3
CDS4040	8	2.4	5.7	1.7	5.6	4.3
CDS4045	8	2.4	6.2	1.9	5.6	4.3
CDS5640	10	3.0	6.3	1.9	8.7	6.7
CDS5653	10	3.0	7.7	2.3	8.7	6.7
CDS5668	10	3.0	9.3	2.8	8.7	6.7
CDS5678	10	3.0	10.3	3.1	8.7	6.7

Table 1: CDS Maintenance Indicators and Sediment Storage Capacities



Suppor

- Drawings and specifications are available at www.contechstormwater.com.
- Site-specific design support is available from our engineers.

©2017 Contech Engineered Solutions LLC, a QUIKRETE Company

Contech Engineered Solutions LLC provides site solutions for the civil engineering industry. Contech's portfolio includes bridges, drainage, sanitary sewer, stormwater, earth stabilization and wastewater treament products. For information, visit www.ContechES.com or call 800.338.1122

NOTHING IN THIS CATALOG SHOULD BE CONSTRUED AS AN EXPRESSED WARRANTY OR AN IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR ANY PARTICULAR PURPOSE. SEE THE CONTECH STANDARD CONDITION OF SALES (VIEWABLE AT WWW.CONTECHES.COM/COS) FOR MORE INFORMATION.

The product(s) described may be protected by one or more of the following US patents: 5,322,629; 5,624,576; 5,707,527; 5,759,415; 5,788,848; 5,985,157; 6,027,639; 6,350,374; 6,406,218; 6,641,720; 6,511,595; 6,649,048; 6,991,114; 6,998,038; 7,186,058; 7,296,692; 7,297,266; 7,517,450 related foreign patents or other patents pending.



CDS Inspection & Maintenance Log

CDS Model:	Location:
CDS WIGHT.	Eocation:

Date	Water depth to sediment ¹	Floatable Layer Thickness ²	Describe Maintenance Performed	Maintenance Personnel	Comments

^{1.} The water depth to sediment is determined by taking two measurements with a stadia rod: one measurement from the manhole opening to the top of the sediment pile and the other from the manhole opening to the water surface. If the difference between these measurements is less than the values listed in table 1 the system should be cleaned out. Note: to avoid underestimating the volume of sediment in the chamber, the measuring device must be carefully lowered to the top of the sediment pile.

2. For optimum performance, the system should be cleaned out when the floating hydrocarbon layer accumulates to an appreciable thickness. In the event of an oil spill, the system should be cleaned immediately.