



Water and Wastewater Capacity Assessment 2024 Year End Report

Town of The Blue Mountains

Water and Wastewater Services Division

Town of The Blue Mountains
32 Mill Street, PO Box 310
Thornbury, Ontario N0H 2P0
Phone: 519-599-3131

Issue Date: March 31, 2025

Table of Contents

Table of Content.....	A
Water and Wastewater Capacity Assessment 2024 Year End Report.....	A
Town of The Blue Mountains.....	A
Abbreviations, Definitions and Units	E
List of Tables	F
List of Graphs	F
Appendices.....	G
Executive Summary.....	1
Water Supply.....	2
1. Total Blue Mountains WTP Capacity.....	2
2. Available Water Capacity	2
Thornbury Wastewater Treatment Plant	3
1. Total Thornbury WWTP Capacity.....	3
2. Available Wastewater Capacity Based on Planning Projections.....	3
3. Thornbury WWTP Estimated Expansion Timeline	3
Craigleith Wastewater Treatment Plant	4
1. Total Craigleith WWTP Capacity	4
2. Available Wastewater Capacity	4
3. Craigleith WWTP Estimated Expansion Timeline.....	4
1.0 Introduction	5
1.1 Purpose	5
1.2 The Blue Mountains Official Plan.....	5
1.2.1 Servicing Policies	5
1.2.2 Development Categories.....	5
1.3 Key Definitions: Allocations versus Reservations	6
1.4 Methodology for Calculating Available Capacity	6
1.4.1 MECP Guideline for Calculating Reserve Capacity	6

1.4.2	Adaptation of MECP Guideline D-5-1 for Year End Reporting.....	7
1.4.3	Application of Historical Data to Determine Per Unit Flow Rates	8
1.4.4	Variations in Planning Versus Actual Units	8
2.0	Population and Service Areas	9
2.1	Historical and Services Population.....	9
3.0	Water Capacity Assessment.....	13
3.1	The Blue Mountains WTP Capacity.....	13
3.1.1	Collingwood Supply.....	13
3.1.2	Total Water Supply.....	13
3.2	Water Demand.....	13
3.2.1	Water Daily Demand.....	13
3.2.2	Top 10 Yearly Maximum Day Demands	14
3.2.3	Monthly Average and Maximum Demand Data	14
3.3	The Blue Mountains WTP and Collingwood Supply Capacity	16
3.3.1	Water Capacity Status.....	16
3.3.2	Allocated and Reserve Capacity.....	16
3.3.3	Flow & Unit Summary	17
3.4	Existing Infrastructure by Pressure Zone	17
3.4.1	Firm Capacity of Existing Water Booster Stations by Pressure Zone.....	17
3.4.2	Pressure Zone 4 (Arrowhead Road BPS)	18
3.4.3	Water Storage Facilities	19
3.5	Infrastructure Leak Index.....	19
4.0	Thornbury Wastewater Capacity Assessment	22
4.1	Thornbury WWTP Capacity.....	22
4.2	Inflow Rates	22
4.3	Total Thornbury WWTP Capacity.....	24
4.3.1	Built & Design Capacity	24

4.3.2	Thornbury WWTP Capacity Status	24
4.3.3	Allocated and Reserve Capacity	25
4.3.4	Flow & Unit Summary	26
4.4	Flow Projections and Estimated Expansion Timeline	26
4.4.1	Phasing of WWTP Expansion	28
4.5	Wastewater Pumping Stations	28
4.5.1	Firm Capacity of Pumping Stations	28
4.6	Peak Day Flow Observations	30
4.6.1	Wastewater Inflow & Infiltration Study (2014)	31
5.0	Craigeith Wastewater Capacity Assessment	31
5.1	Craigeith WWTP Capacity	31
5.2	Inflow Rates	31
5.3	Total Craigeith WWTP Capacity	33
5.3.1	Built Capacity	33
5.3.2	Craigeith WWTP Capacity Status	33
5.3.3	Allocated and Reserve Capacity	34
5.3.4	Flow & Unit Summary	35
5.4	Wastewater Pumping Stations	35
5.4.1	Firm Capacity of Pumping Stations	35
5.4.2	Craigeith Main Wastewater Pumping Station	37
5.5	Peak Day Flow Observations	38
5.5.1	Wastewater Inflow & Infiltration Study (2014)	39
6.0	Conclusions and Recommendations	39
	Appendix A – Figure 1 – Development Staging Process	41
	Appendix B – 2024 Water and Wastewater Servicing Maps	42
	Appendix C – Water Pressure Zone Boundary Map	45
	Appendix D – 2024 Capacity Chart	46

Appendix E – WTP 10 Water Demands..... 47

Appendix F – Thornbury WWTP - 2023 and 2024 Top 10 Peak Flows..... 48

Appendix G – Craigleith WWTP – 2023 and 2024, Top 10 Peak Flows..... 49

Appendix H – Basis for Calculating Equivalent Units 50

Abbreviations, Definitions and Units

Term or Abbreviation	Definition
ADD	Average Day Demand m ³ /d (water): Total yearly demand divided by 365 days.
ADF	Average Day Flow m ³ /d (wastewater): Total yearly flow divided by 365 days.
Built Capacity	Servicing capacity of existing built Town water and WWTP facilities and associated infrastructure.
BPS	Water Booster Pumping Station
CPUB	Town of Collingwood
Design Capacity	Servicing capacity of planned Town water capacity and wastewater treatment facilities and associated infrastructure based on designed and approved capacity, typically available when an ECA is obtained.
ICI	Industrial, Commercial, and Institutional
ILI	Infrastructure Leak Index
I&I	Inflow and Infiltration
EA	Environmental Assessment
ECA	Environmental Compliance Approval issued by MOECC
ESR	Environmental Study Report
Firm Capacity	Capacity available from infrastructure with largest component out of service.
kg/d	Kilograms per day
L/s	Litres per second
L/unit/day	Litres per equivalent unit per day
Leachate	A solution resulting from downward percolation of ground water through material.
m³/d	Cubic meters per day
m³/unit/d	Cubic meters per equivalent unit per day
MDD	Maximum Day Demand m ³ /d (water)
MDF	Maximum Day Flow m ³ /d (wastewater)
MECP	Ministry of the Environment, Conservation and Parks
PDF	Peak Day Flow m ³ /d (wastewater)
Pressure Zone	Area including a lower and upper elevation that receives water from a hydraulic grade line.
psi	Pounds per square inch
Res.	Residential
Service Area	Settlement area identified in the Town's Official Plan that includes water and wastewater servicing.
Town	Town of The Blue Mountains
WTP	The Blue Mountains Water Treatment Plant
WW	Wastewater
WWPS	Wastewater Pumping Station
WWTP	Wastewater Treatment Plant

List of Tables

Table #	Title	Page #
2.1	Census Canada Population Data	9
2.2	Town Water System Equivalent Serviced Population	10
2.3a	Thornbury Wastewater System Equivalent Serviced Population	11
2.3b	Craigleith Wastewater System Equivalent Serviced Population	11
2.3c	Town Wastewater System Equivalent Serviced Population (Thornbury & Craigleith)	12
3.1	Five Year Rolling Average Water Demands	13
3.2	2024 Water Unit Status	17
3.3	Summary of Water Storage Capacity by Pressure Zone	20
3.4	Summary of Water Produced, Consumed and Lost	22
4.1	Thornbury WWTP Historical Flows	23
4.2	2024 Thornbury WWTP Unit Status	25
5.1	Craigleith WWTP Historical Flows	28
5.2	2024 Craigleith WWTP Unit Status	30
6.1	Summary of Capacity Status for Key Infrastructure (Units)	34

List of Graphs

Graph #	Title	Page #
2.1	2015-2024 Equivalent Water Units: Residential and ICI	10
2.2	2015-2024 Equivalent Wastewater Units: Residential and ICI	12
3.1	2015-2024 Average Day and Maximum Day Water Demands and Connected Units Status	14
3.2	2024 Monthly, Average and Maximum Day Water Demand	15
3.3	Water Supply and Demand Summary	17
3.4	ILI Value 2015-2024	20
4.1	Thornbury WWTP Unit Status, Average Day Flow and Peak Day Flow	23
4.2	Thornbury WWTP Summary	26
4.3	Thornbury WWTP Projections (Units)	27
5.1	Craigleith WWTP Unit Status, Average Day Flow and Peak Day Flow	31
5.2	Craigleith WWTP Summary	33
5.3	Craigleith WWPS Historical and Projected Flows 2013-2027	35

Appendices

Appendix A	Figure 1: Development Staging Process
Appendix B	Water and Wastewater Service Maps <ul style="list-style-type: none">• Water Servicing• Wastewater Servicing
Appendix C	Water Pressure Zone Boundary Map
Appendix D	2024 Capacity Chart
Appendix E	Thornbury WTP 2023 and 2024 Top 10 Maximum Day Demands
Appendix F	Thornbury WWTP 2023 and 2024 Top 10 Peak Flows
Appendix G	Craighleith WWTP: 2023 and 2024 Top 10 Peak Flows
Appendix H	Basis for Calculating Equivalent Units

Executive Summary

This report provides an assessment of water and wastewater treatment systems capacity within the Town for 2024. The current Town water supply and wastewater treatment infrastructure includes:

- The Blue Mountains Water Treatment Plant & Distribution System
- Supplemental water supply from the Town of Collingwood
- Thornbury Wastewater Treatment Plant & Collection System
- Craigeleith Wastewater Treatment Plant & Collection System

According to Ministry of the Environment Conservation and Parks (MECP) Guideline D-5-1 entitled “Calculating and Reporting Uncommitted Reserve Capacity at Sewage and WTPs”, “The number of lots in approved plans of subdivisions, developments committed by virtue of approved zoning, new official plans or site-specific official plan amendments, should not exceed the design capacity of the sewage and/or water system. To ensure that capacity is not exceeded it is necessary to determine what uncommitted reserve capacity is available. This procedure provides a means for determining uncommitted reserve capacity.”¹ *** See note in TWWTP for modified calculation method.

Key Definitions: Allocations versus Reservations

Built capacity Servicing capacity of existing built Town WTP and WWTP facilities and associated infrastructure (e.g. distribution and collections systems).

Design capacity Servicing capacity of planned Town water supply and wastewater treatment facilities and associated infrastructure based on designed and approved capacity, typically available when an ECA is obtained.

Allocation* Commitment of built plant capacity; and “allocation of servicing capacity” or “allocated servicing capacity” shall have a corresponding meaning.

Reservation* Commitment of approved design capacity, available when design is completed, and approvals are obtained and “reservation of servicing capacity” or “reserved servicing capacity” shall have a corresponding meaning.

* To determine units available for allocation, built capacity will be used. To determine units available for reservation, planned and approved capacity (e.g. facility design complete, ECA obtained) will be used. If no planned or approved capacity is available, the total capacity for reservation and allocation is the built capacity.

¹ MECP guideline D-5-1 entitled, “Calculating and Reporting Uncommitted Reserve Capacity at Sewage and WTPs”, updated March 1995.

Water Supply

1. Total Blue Mountains WTP Capacity

The firm capacity available from the Blue Mountains WTP is 15,140 m³/day. The Town receives up to 1,250 m³/day supplemental supply from the Town of Collingwood.


Therefore, the total firm water capacity available is 16,390 m³/day or 16,357 units based on the 5-year rolling MDD of 1.002 m³/unit/day.

2. Available Water Capacity

A total demand of 10,929 m³/day (10,907 units) is currently connected or allocated to the water system based on a 5-year rolling average maximum daily demand of 1.002 m³/unit/day.

A total flow of 2,553 m³/day (2,548 units) is currently reserved at 1.002 m³/unit/day.

Of the 16,357 total units of water supply available, there are currently 13,455 units allocated and reserved. Therefore, the current available capacity of the Town's water supply is 2,902 units.



Thornbury Wastewater Treatment Plant

1. Total Thornbury WWTP Capacity

The total firm ADF built capacity available at the Thornbury WWTP is 3,580 m³/day or 4,355 units based on the 5-year rolling ADF of 0.822 m³/unit/day.

2. Available Wastewater Capacity Based on Planning Projections

A total flow of 3,044 m³/day (3,703 units) is currently connected or allocated to the Thornbury WWTP based on a 5-year rolling ADF. There are currently 3,703 units allocated and 172 reserved. Therefore, using planning projections the current available uncommitted reserve capacity based on built capacity is 480 units. However, as shown below not all units are physically connected.


The Thornbury WWTP is quickly approaching capacity based on allocated and reserved units. However, there are 459 units (172 reserved + 287 can connect) which are not physically connected to the Thornbury WWTP.

The MECP guideline for Year End reporting has been modified through discussion between the Town, Grey County and the MECP. The purpose of the modified method is to optimize the use of the Thornbury WWTP built capacity prior to commencing construction of additional capacity. Upon completion of construction of all proposed Phase 1A works, for which the Town has approval to construct, the ADF Design Capacity available will be 5,330 m³/d or 6,484 units based on an ECA received in 2019. Therefore, the current available uncommitted reserve capacity based on design capacity is 2,609 units.

The PDF flow at the Thornbury WWTP in 2024 was 7,482 m³/day. The design PDF for the Thornbury WWTP is 7,196 m³/d. The PDF typically occurs during a period of snow melt or a significant wet weather event. The peak day occurred on December 30, during a snow melt event. The peak flow event did exceed the peak capacity of the treatment plant.

3. Thornbury WWTP Estimated Expansion Timeline

The Town has commenced with the expansion of the Thornbury WWTP. It is anticipated that the work will be completed in the second quarter of 2025. The Thornbury WWTP is operating at 74% of the built capacity based on a 5- year rolling average.



Craigleith Wastewater Treatment Plant

1. Total Craigleith WWTP Capacity

The total firm ADF built capacity available at the Craigleith WWTP is 8,133 m³/day or 13,118 units based on the 5-year rolling ADF of 0.620 m³/unit/day.


2. Available Wastewater Capacity

A total flow of 3,729 m³/day (6,015 units) is currently connected or allocated to the Craigleith WWTP, based on a 5-year rolling ADF. There are currently 6,015 units allocated and 2,571 units reserved. Therefore, the current uncommitted reserve capacity on built capacity is 4,532 units.

The PDF flow at the Craigleith WWTP in 2024 was 8,752 m³/day. This was on December 30, 2024. The design PDF for the Craigleith WWTP is 19,640 m³/d. The PDF typically occurs during a period of significant wet weather or a snow melt event.

3. Craigleith WWTP Estimated Expansion Timeline

Based on the 2024 five (5) year rolling ADF of 3,428 m³/day, the Craigleith WWTP is operating at 42% of the built capacity and as such, there is no immediate need to expand the Craigleith WWTP.



1.0 Introduction

1.1 Purpose

This report provides an assessment of water and wastewater treatment capacity within the Town of The Blue Mountains (Town) for 2024. The current Town water and wastewater supply and treatment infrastructure includes:

- The Blue Mountains Water Treatment Plant & Distribution System
- Supplemental water supply from the Town of Collingwood
- Thornbury Wastewater Treatment Plant & Collection System
- Craighleith Wastewater Treatment Plant & Collection System

In addition, this report provides a review of the capacity of water storage reservoirs, BPS, WWPS and identifies current or proposed system upgrades or expansion projects.

1.2 The Blue Mountains Official Plan

1.2.1 Servicing Policies

Section D1 of the Official Plan outlines the Town’s servicing policies. It identifies the preference for municipal water and wastewater servicing requirements for each Service Area within the Town, establishes policies for the provision of private or municipal water and wastewater servicing, defines requirements for servicing of existing residents, as well as reservation and allocation limitations and requirements for new development.

Section D1.4 of the Official Plan describes five development-staging categories based on development approval status and the corresponding level of commitment of WTP or WWTP infrastructure capacity. The process makes commitment of capacity for existing unserviced development. Figure 1 in Appendix A provides an overview of the development staging process and requirements for moving through the process for both new and existing unserviced development. Development is identified as having “No Capacity”, “Reservation”, or “Allocation” depending on the stage.

Development staging categories identified in Section D of the Official Plan correspond with the development categories used in the Year End Report as identified in Figure 1, and as discussed below.

1.2.2 Development Categories

The Town’s Year End Reports have historically identified 7 categories of connection status within the Town. See Appendix A.

1. Connected – includes all connected units
2. Can connect – includes all existing units and vacant lots fronting servicing that are not connected
3. Committed – includes all new units that are identified in an executed development agreement
4. Not fronting, Not Serviced – includes existing units and vacant lots within a service area that do not front servicing
5. Designated active lands – includes units in areas with draft plan approval

6. Other lands designated – includes units in areas that are designated but do not have draft plan approval
7. Other lands not designated – includes units in areas that require Official Plan Amendments and have no approval

1.3 Key Definitions: Allocations versus Reservations

Built capacity	Servicing capacity of existing built Town WTP and WWTP facilities and associated infrastructure (e.g. distribution and collections systems).
Design capacity	Servicing capacity of planned Town water supply and wastewater treatment facilities and associated infrastructure based on designed and approved capacity, typically available when an ECA is obtained.

Allocation* Commitment of built plant capacity; and “allocation of servicing capacity” or “allocated servicing capacity” shall have a corresponding meaning.

Reservation* Commitment of approved design capacity, available when design is completed, and approvals are obtained and “reservation of servicing capacity” or “reserved servicing capacity” shall have a corresponding meaning.

* To determine units available for allocation, built capacity will be used. To determine units available for reservation, planned and approved capacity (e.g. facility design complete, ECA obtained) will be used. If no planned or approved capacity is available, the total capacity for reservation and allocation is the built capacity.

1.4 Methodology for Calculating Available Capacity

The following sections describe the methodology used to calculate the uncommitted capacity available for “reservation” and “allocation” as defined above. The approach has been adapted from the MECP Guideline as described below.

1.4.1 MECP Guideline for Calculating Reserve Capacity

The MECP has a Guideline D-5-1 entitled “Calculating and Reporting Uncommitted Reserve Capacity at Sewage and WTPs”. The latest revision is March 1995. The reserve capacity calculation is intended to ensure that committed developments do not exceed the design capacity of the wastewater and/or water works.

In general, the Guideline recommends calculating reserve capacity as follows:

Reserve Capacity = Approved Design Capacity – Existing Flows – Committed Flows

Where: Approved Design Capacity of a WTP or a WWTP is described as the capacity that may be defined in a Design Report or the Environmental Compliance Approval.

Existing Flows is the flow based on a rolling average of five (5) year historical flow (average inflow for WWTPs, peak inflow for wastewater pumping stations, maximum day demand for WTPs and peak day demand for BPS).

Committed Flows includes all units identified as can connect, committed, not fronting, not serviced and designated active lands.

The MECP suggests that the calculation may be modified to account for any of the following deviations:

- Widely variable seasonal flow fluctuations due to infiltration or seasonal population.
- Rapid development/growth which may dramatically increase the forecasted flows.

- Large industrial facilities which may impact flows.
- Per capita flow projection which may be substantially different from historical flows.

In addition, operating conditions at water and wastewater treatment facilities may necessitate the need to modify the formula to account for capacity loss. For example, a facility may have a deficiency and is not capable of meeting its approved design capacity, or water quality/effluent quality parameter.

1.4.2 Adaptation of MECP Guideline D-5-1 for Year End Reporting

The MECP Guideline D-5-1 entitled “Calculating and Reporting Uncommitted Reserve Capacity at Sewage and WTPs”, as discussed above, has been adapted for use in calculating capacity at the Town’s treatment facilities.

The following provides an overview of the formula and method of applying historical data to be used in the subsequent sections of this document. The MECP Procedure for Calculating and Reporting Uncommitted Reserve Capacity, permits three to five (5) years of records to be used in establishing representative MDDs. The Town has utilized a five (5) year rolling average in its Year End Reports.

The following calculation is used to determine total facility capacity (units):

$$\text{Total Facility Capacity (units)} = \frac{\text{Facility Built or Design Capacity (m}^3\text{/day)}}{5 \text{ Year Rolling Per Unit Flow Rate (m}^3\text{/unit/day)}}$$

The Facility Built Capacity (m³/day) – The total flow that can be treated by the built capacity of the facility based on historical average flows.

Total Facility Design Capacity (units) – Units available for reservation based on planned and approved capacity (design complete, ECA obtained, but not built). If no planned or approved capacity is available, the capacity available for reservation and allocation is the plant-built capacity. It is recognized that the number of units that can be serviced will change from year to year because the per unit flow rate will change with time.

Per Unit Flow Rate (m³/unit/day) - Determined based on a review of historical data as discussed in Section 1.4.3.

If the units available for allocation is negative (e.g. Total Facility Built Capacity (Units) < total units allocated), the facility is over allocated and additional capacity is required. Although this would indicate that the facility would receive flows or demands higher than the operating capacity, it is noted that units identified in Categories 2 and 3 are not necessarily connected. However, the Town is obligated to service units in Categories 2 and 3 and thus must ensure that the capacity is available when a connection is made.

If the units available for reservation is negative (e.g. Total Facility Design Capacity (Units) < total units allocated + total units reserved), then an ECA is required to increase the Design Capacity of facility to allow for additional reservation of servicing capacity.

Total Units Allocated*.... is the sum of units identified in development categories 1 to 3.

Total Units Reserved*....is the sum of units identified in development category 5.

* Note: Development categories are defined under section 1.2.2

The above methods for calculations have been further modified for the Thornbury WWTP (see section 5.0)

1.4.3 Application of Historical Data to Determine Per Unit Flow Rates

To ensure that the per unit flow rate adequately represents credible flows / demands, an assessment of monthly and peak data for five (5) years is analysed to determine a five (5) year rolling average. There are two main reasons for adopting this approach. Firstly, to accommodate for variances in flows and demands based on weather patterns and reduce fluctuation in the per unit flow rate on a yearly basis; and secondly, to ensure that changes in demands related to demographic shifts and changing development do not overly influence the criteria. These two issues are further discussed below.

Water

Maximum day water demands are used to size water treatment facilities and are generally influenced by seasonal factors because peak per unit demands during hot, dry summer periods are higher than those experienced during wet, cooler summers. Using a historical five (5) year rolling average to establish the per unit MDD rate will ensure that yearly changes in demands due to weather patterns do not unduly influence the MDD rate and the potential impact of anomalies in data can be mitigated.

Wastewater

Wastewater average daily flows are used to size wastewater treatment facilities and are generally influenced by seasonal factors due to use of summer and winter facilities by residents and tourists. Typical wet weather flows occur in the spring and fall of each year. Using a five (5) year rolling ADF to establish the per unit ADF rate will ensure that yearly changes in demands due to weather patterns do not unduly influence the ADF rate and potential impact of anomalies in data can be mitigated.

The calculation of WWPS capacity is based on historical instantaneous peak flows since there is quite limited capacity to store wastewater or mitigate an increase in flow like a WWTP.

In summary, the following data will be reported and used to determine the per unit flow rate.

Per Unit Maximum Day Water Demand (MDD/unit) – five (5) year rolling average maximum day demand that occurred within the record period.

Per Unit Average Day Wastewater Flow (ADF/unit) – five (5) year rolling average daily flow that occurred over the record period.

Per Unit Peak Wastewater Flow (PDF/unit) - Maximum instantaneous peak daily flow that occurred over the record period.

Firm Capacity - Capacity of a facility with the largest mechanical unit out of service.

1.4.4 Variations in Planning Versus Actual Units

Throughout the Report there is a small variation noted in the Planning projections versus actual number of units. In 2009, the way the connected units were compiled resulted in a slight discrepancy in the numbers from Planning and the numbers from Infrastructure & Public Works. Recently the numbers were migrated from previous spread sheets to the current GIS format and the discrepancy has followed.

Planning Staff undertook a thorough investigation and a comprehensive analysis of the connected units to both the water and wastewater systems for the 2021-unit count. This analysis included utilizing the Town's GIS database, billing database, Google Earth and in some instances, an actual walk through of areas. Significant changes were made, and when it was apparent that unit count had been incorrect for several years, the connected units were changed back to 2012.

2.0 Population and Service Areas

The following sections review population data for the Town and discuss the service areas within the Town and their respective servicing requirements as identified in the Official Plan. The different service areas are outlined on the maps in Appendix B. The population data reviewed in this section is used to project total equivalent population. Capacity status reporting is done on a per equivalent unit basis to account for fluctuations in permanent population. However, it is important to monitor population density with time because a change in per unit density may correspond with a change in per unit flow rates. The Town may experience changes in unit densities due to demographic shifts and as seasonal residences become permanent residences.

2.1 Historical and Services Population

Table 2.1 tabulates the number of units and population from Census Canada for 2001, 2006, 2011, 2016 and 2021. The table represents only the permanent residential units and population. Census Canada only tabulates occupants at their principal residence (not seasonal residences).

Table 2.1 Census Canada Population Data

Blank	Grey County			The Blue Mountains		
Year	Total Units	Population	Persons/Unit	Total Units	Population	Persons/Unit
2001	35,325	89,073	2.52	2,585	6,116	2.37
2006	37,185	92,411	2.49	2,939	6,825	2.33
2011	38,042	92,568	2.43	2,846	6,452	2.27
2016	39,563	93,830	2.37	3,271	7,025	2.15
2021	42,704	100,905	2.36	4,350	9,390	2.15

From Table 2.1, the unit density for permanent residents in the Town was 2.15 persons per unit in 2021. This figure is slightly lower than the Grey County density of 2.36 persons per unit, which dropped slightly from the previous census. Although these figures do not include the significant seasonal component of the Town's population, they are the most accurate figures available for estimating the unit density at this time. Thus, the unit residential density of 2.15 will be used for permanent and part time units.

Tables 2.2 and 2.3a, 2.3b and 2.3c tabulate the number of equivalent units and population serviced by the Town's water and wastewater systems. Industrial, Commercial, and Institutional units are included as equivalent units, whereas the residential component is actual units (including permanent and seasonal units).

Table 2.2 Town Water System Equivalent Serviced Population

Water Units				
Year	Residential Water Units	Equivalent ICI Water Units**	Total Equivalent Water Units	Total Equivalent Served Population*
2015	5,018	3,241	8,259	18,748
2016	5,144	3,261	8,405	18,071
2017	5,485	3,124	8,609	18,509
2018	5,718	3,136	8,854	19,036
2019	5,977	3,076	9,053	19,464
2020	6,269	3,088	9,357	20,118
2021	6,631	3,088	9,719	20,896
2022	6,888	3,094	9,982	21,461
2023	7,050	3,115	10,165	21,855
2024	7,114	3,116	10,230	21,995

*Equivalent service population is based on the Census Canada unit density for the Town of The Blue Mountains as described in Table 2.1. The Total Equivalent Water Units is multiplied by the current unit density of 2.15.

**Equivalent ICI Water units are based on Ainley and Associates 1985 “Basis for Equivalent Units” File No. 81170 (see Appendix H).




Table 2.3a Thornbury Wastewater System Equivalent Serviced Population

Wastewater Units – Thornbury WWTP				
Year	Thornbury Residential WW Units	Thornbury Equivalent ICI WW Units	Thornbury Total Equivalent WW Units	Equivalent Serviced Population* Thornbury WWTP
2015	1,942	579	2,521	5,723
2016	1,993	579	2,572	5,530
2017	2,088	580	2,668	5,736
2018	2,161	582	2,743	5,897
2019	2,256	582	2,541	5,463
2020	2,333	612	2,945	6,332
2021	2,518	612	3,130	6,729
2022	2,662	612	3,274	7,039
2023	2,767	632	3,399	7,308
2024	2,784	632	3,416	7,344

*Equivalent service population is based on the Census Canada unit density for the Town of The Blue Mountains as described in Table 2.1. The Total Equivalent WW Units is multiplied by the current unit density of 2.15.

Table 2.3b Craigeleith Wastewater System Equivalent Serviced Population


Wastewater Units – Craigeleith WWTP				
Year	Craigeleith Residential WW Units	Craigeleith Equivalent ICI WW Units	Craigeleith Total Equivalent WW Units	Equivalent Serviced Population* Craigeleith WWTP
2015	2,415	2,176	4,591	10,421
2016	2,483	2,178	4,661	10,021
2017	2,448	2,318	4,766	10,247
2018	2,617	2,318	4,935	10,610
2019	2,794	2,256	5,050	10,858
2020	3,005	2,268	5,273	11,337
2021	3,175	2,268	5,443	11,702
2022	3,312	2,275	5,587	12,012
2023	3,377	2,295	5,672	12,195
2024	3,424	2,296	5,720	12,298

*Equivalent service population is based on the Census Canada unit density for the Town of The Blue Mountains as described in Table 2.1. The Total Equivalent WW Units is multiplied by the current unit density of 2.15.

Table 2.3c Town Wastewater Systems Equivalent Serviced Population (Thornbury & Craigleith)

Wastewater Units				Equivalent Serviced Population*		
Year	Residential WW Units Craigleith & Thornbury	Equivalent ICI WW Units Craigleith & Thornbury	Total Equivalent WW Units	Craigleith WWTP	Thornbury WWTP	Total Population
2014	2,361 + 1,903 = 4,264	2,176 + 615 = 2,791	7,055	10,299	5,716	16,015
2015	2,415 + 1,942 = 4,357	2,176 + 579 = 2,755	7,112	10,421	5,723	16,144
2016	2,483 + 1,993 = 4,476	2,178 + 579 = 2,757	7,233	10,021	5,530	15,951
2017	2,448 + 2,088 = 4,536	2,318 + 580 = 2,898	7,434	10,247	5,736	15,983
2018	2,617 + 2,161 = 4,778	2,318 + 582 = 2,900	7,678	10,610	5,897	16,507
2019	2,794 + 2,256 = 5,050	2,256 + 582 = 2,838	7,888	10,858	5,463	16,321
2020	3,005 + 2,333 = 5,338	2,268 + 612 = 2,880	8,218	11,337	6,332	17,669
2021	3,175 + 2,518 = 5,693	2,268 + 612 = 2,880	8,573	11,702	6,729	18,431
2022	3,312 + 2,662 = 5,974	2,275 + 612 = 2,887	8,861	12,012	7,039	19,051
2023	3,337 + 2,767 = 6,144	2,295 + 632 = 2,927	9,071	12,195	7,308	19,503
2024	3,424 + 2,784 = 6,208	2,296 + 632 = 2,928	9,136	12,298	7,344	19,642

*Equivalent service population is based on the Census Canada unit density for the Town of The Blue Mountains as described in Table 2.1. The Total Equivalent WW Units is multiplied by the current unit density of 2.15.



3.0 Water Capacity Assessment

3.1 The Blue Mountains WTP Capacity

The Blue Mountains WTP draws water from Georgian Bay for treatment and distribution. The WTP uses microfiltration, ultraviolet irradiation and gas chlorine disinfection for the treatment of water. The firm capacity of the WTP is 15,140 m³/day.

3.1.1 Collingwood Supply

A water supply agreement was signed in 2015 by the Town and the Town of Collingwood for the purchase of up to 1,250 m³/day on a permanent basis from Collingwood. Water is supplied from the Collingwood Water System via the Mountain Road BPS. In addition to the Mountain Road BPS, the Collingwood Water System provides water to the Crestview development on Grey Road 21. The Town of Blue Mountains provides water to Collingwood residents along Long Point Road.

3.1.2 Total Water Supply

The total available firm capacity including the WTP and supply from Town of Collingwood is 16,390m³/day, (15,140 + 1,250).

3.2 Water Demand

3.2.1 Water Daily Demand

The following table, which includes the supplemental supply from Town of Collingwood, summarizes the annual average day demand (ADD) and maximum day demand (MDD) from 2015 to 2024. For the purposes of calculating the total capacity required, the MDD is used.

Table 3.1 Five (5) Year Rolling Average Water Demands


Year	# of Units	ADD (m ³ /d)	ADD (m ³ /unit/d)	5 Year Rolling Average ADD (m ³ /unit/d)	MDD (m ³ /d)	MDD (m ³ /unit/d)	5 Year Rolling Average MDD (m ³ /unit/d)
2015	8,259	4,591	0.556	0.511	8,721	1.056	1.036
2016	8,405	4,940	0.588	0.518	8,950	1.065	0.994
2017	8,609	4,680	0.544	0.514	7,838	0.910	1.044
2018	8,854	4,911	0.555	0.528	8,582	0.969	0.972
2019	9,053	5,389	0.595	0.568	9,507	1.050	1.010
2020	9,357	5,699	0.609	0.578	9,959	1.064	1.012
2021	9,719	6,087	0.626	0.586	9,635	0.991	0.997
2022	9,982	6,005	0.602	0.597	9,753	0.997	1.014
2023	10,165	6,412	0.631	0.613	10,362	1.019	1.024
2024	10,230	5,948	0.581	0.610	9,631	0.941	1.002
		2024 5 Year Rolling ADD/Unit = 0.610 m ³ /unit/day			2024 5 Year Rolling MDD/Unit = 1.002 m ³ /unit/day		

3.2.2 Top 10 Yearly Maximum Day Demands


Tables A16 to A17 in Appendix E summarize the top ten highest demands that occurred in 2023 and 2024. Maximum day water demands typically occur during the summer period when water use increases due to activities such as lawn watering, the ten highest demand days for 2024 were in July and August. The MDD in 2024 was on August 4, 2024 (9,631m³).

3.2.3 Monthly Average and Maximum Demand Data

Graph 3.1 below illustrates the comparison of average and maximum day water demands from 2015-2024. While the number of connected units rises gradually each year, there is a slight increase in the average water demand since 2015. The maximum daily water demand has been increasing between 2014 and 2023, however, there was a slight decrease in 2024. Cooler wet summers result in slightly lower maximum daily water demand, while hot dry summers result in a slightly higher maximum daily water demand, due to increase water taking for irrigation purposes.



A comparison of average to maximum day water consumption for 2024 is illustrated in Graph 3.2 below. The monthly demands tend to decline during spring and fall months and increase during summer and winter months.



3.3 The Blue Mountains WTP and Collingwood Supply Capacity

As discussed in Section 3.1, the firm capacity available from The Blue Mountains WTP in 2024 was 15,140 m³/day and the supplemental supply from Collingwood was 1,250 m³/day. Therefore, the total built capacity is 16,390 m³/day.

Using the per unit rolling five (5) year MDD from Table 3.1 to determine the total number of units that can be supplied, results in the following:

$$\text{Built Capacity: } \frac{16,390 \text{ m}^3/\text{day}}{1.002 \text{ m}^3/\text{unit}/\text{day}} = 16,357 \text{ units}$$

Therefore, the Total Built Capacity is 16,357 units.

3.3.1 Water Capacity Status

Table 3.2 summarizes the 2024 capacity status. A breakdown of the water supply capacity status is included in Appendix D.

Table 3.2 2024 Water Unit Status

Year End Report Category	Official Plan Capacity Status	Number of Units	Demand (m ³ /d)*
1. Connected	Allocated	10,230	10,251
2. Can Connect	Allocated	677	678
3. Committed	Allocated	0	0
Sub-Total Allocated (1+2+3)		10,907	10,929
4. Not Fronting, Not Serviced	Reserved	819	821
5. Designated Lands – Active	Reserved	1,729	1,732
Sub-Total Reserved (4+5)		2,548	2,553
Total Can Connect + Committed + Not Fronting, Not Serviced + Designated Lands Active (2+3+4+5)		3,225	3,231
Total Allocated + Reserved (1+2+3+4+5)		13,455	13,482
6. Designated Lands – Other	Not Recognized	7,293	7,308
7. Not Designated	Not Recognized	3,154	3,160
Sub-Total Not Recognized (6+7)		10,447	10,468
Grand Total (1+2+3+4+5+6+7)		23,902	23,950

* number of units multiplied by the 5-year rolling average MDD identified in Table 3.1

3.3.2 Allocated and Reserve Capacity

Using data from Tables 3.1 and 3.2, reserve capacity for the Town's Water Supply is determined using the calculation from Section 1.4.2

Total Built Capacity = 16,357 units (as identified in Section 3.3)


Connected Demand = 10,230 units (connected units as identified in Table 3.2)

Reserved Demand = 3,225 units (total reserved units as identified in Table 3.2)

Therefore: **Units Available for Reservation** = $16,357 - 10,230 - 3,225 = 2,902$ units

3.3.3 Flow & Unit Summary

Graph 3.3 below summarizes the Town's water supply and demand



The WTP has adequate capacity to support existing system users and development. Consideration for additional capacity will be required as demand and the user base continue to grow.

Currently the WTP has three (3) microfiltration trains providing a firm capacity of 15,140 m³/day. Ultimate built WTP capacity will include an additional two (2) microfiltration trains for a total of five (5). These five (5) trains will provide the Town with a firm capacity of 30,280 m³/day. However, other modifications to the WTP to realize this capacity, including modifications to the clearwell, pumping capacity and transmission capacity.

A solution to the Town's long-term water supply needs is currently being addressed through the Eastside Water Storage and Supply Class Environmental Assessment project. It anticipated the EA will be completed in early 2025.

3.4 Existing Infrastructure by Pressure Zone

Although the water supply is adequate for the Town's water demand, individual components of the distribution system can be inadequate and therefore a review of key components is warranted.

3.4.1 Firm Capacity of Existing Water Booster Stations by Pressure Zone

The following is a list of existing storage facilities and booster stations within each Pressure Zone currently receiving the Town's water supply and their respective firm capacities. Appendix C Water Pressure Zone Boundary Map illustrates the boundaries of Pressure Zones 1-5.

Craigleith – Pressure Zone 4

- Existing storage reservoir capacity is 5,000 m³.
- Arrowhead Road Booster Station has a firm capacity of 68 L/s.
- Mountain Road Booster Station has an operating limit of 14.5 L/s reflecting the Collingwood Agreement but is physically capable of supplying 46 L/s that may be utilized with prior consent from Collingwood.

Swiss Meadows – Pressure Zone 5

- Water Storage Standpipe has a reservoir capacity of 536 m³.
- Happy Valley Booster Station has a firm capacity of 5 L/s.

Camperdown – Pressure Zone 1 & 3

- Camperdown Reservoir and Booster Station has a reservoir capacity of 2,662 m³ and a firm capacity of 25 L/s.
- Camperdown Court Booster Station has a firm capacity of 85 L/s
- Wards Road Booster Station has a firm capacity of 16 L/s

Thornbury – Pressure Zone 1

- Elevated Water Tower has a capacity of 747 m³.

Thornbury Reservoir and BPS has a reservoir capacity of 3,400 m³ and a firm capacity of 174 L/s.

Lora Bay – Pressure Zone 2

- 10th Line Booster Station has a firm capacity of 100 L/s.

3.4.2 Pressure Zone 4 (Arrowhead Road BPS)

The Arrowhead Road BPS and the supplemental water supply from Collingwood provide water to the Craigleith Service Area (Pressure Zone 4) and Swiss Meadows (Pressure Zone 5). The BPS is also able to direct supplemental water supply from Collingwood to pass through the station to Pressure Zone 1 when necessary.

As noted in Section 3.3.1, the firm capacity of the Arrowhead Road BPS is 68 L/s or 5,875 m³/day and the supply available from Collingwood is 14.5 L/s or 1,250 m³/day. Therefore, a total of 7,125 m³/day can be supplied to Pressure Zone 4 and Pressure Zone 5.

Using the 5-year rolling average of the per unit MDD to determine the total number of units that can be supplied results in the following:

$$\frac{7,125 \text{ m}^3/\text{day}}{1.002 \text{ units}/\text{m}^3/\text{day}} = 7,111 \text{ units}$$

Currently, 6,766 units in Pressure Zones 4 and 5 are connected or have received allocation (Categories 1 to 3). Based on the design capacity reported above, the current available allocation capacity for the Zone 4 and 5 is 345 units or 346 m³/day (7,111 – 6,766 = 345 units).

Existing reservoirs and Pump Stations are capable of meeting historical water demands. The findings of the East Side Storage and Supply Class Environmental Assessment will determine the upgrade requirements. In 2023 the Town commenced with the Engineering to increase the capacity of the Arrowhead Booster Pumping Station. The goal of the assignment is to replace the 28 l/s pump with a 80 l/s pump. The firm capacity of the station will be increased from 68 l/s to 120 l/s, however there may be limitations with the transmission main feed to the station being able to convey that volume of water.

3.4.3 Water Storage Facilities

Table 3.3 summarizes the existing water storage facilities within the Town's water system, the servicing capacity of each facility and the number of approved units within the Pressure Zones.

Storage capacity has three main components: emergency, fire, and equalization storage.

Table 3.3 Summary of Water Storage Capacity by Pressure Zone

Pressure Zone	Storage Capacity (m ³)
Craigleith (Pressure Zone 4)	5,000
Swiss Meadows (Pressure Zone 5)	536
Camperdown (Pressure Zone 3)	2,662
Thornbury (Pressure Zone 1)	4,180
Total Existing	12,378 m ³

A Pressure Zone analysis completed by C3 Water Inc. in "Technical Memorandum 6: Upgrade Implementation Plan" dated August 9, 2016, stated that:

- Pressure Zones 1 & 2 have an existing deficit of 2,500 m³ requiring the addition of storage.
- Pressure Zones 3 & 5 have sufficient storage to meet present and future demands (to build out in 2033).
- Pressure Zone 4 will have sufficient storage to meet 2033 requirements if the pumping capacity of Arrowhead BPS is upgraded.

In 2018, the Town undertook a Town-Wide Water Distribution Master Plan Class Environmental Assessment, (Water MPEA), to establish a long-term solution for the provision of water servicing. Followed by the West-side Water Storage Municipal Class Environmental Assessment (MCEA) to address the drinking water storage and pumping capacity deficiencies in West Pressure Zones 1, 2 and 3. The preferred solutions included rehabilitation of the existing Victoria Street water tower, construction of a new water reservoir at the 10th Line Booster Station, an additional new feedermain from the 10th Line Booster Station to the intersection of Lora Bay Drive and West Ridge Drive, and pump upgrades at the Upper Camperdown Booster Pumping Station. The Town's Victoria Street Water Tower was rehabilitated in 2023. The engineering for the Camperdown Booster is under way, with construction anticipated for 2025.

The Town also has commenced with the Engineering upgrade to the Arrowhead Booster Station. The works include replacing the 28 l/s pump with a 80 l/s pump, and increasing the firm capacity of the station to 120 l/s.

In 2021, the Town initiated an East-side Water Storage and Supply MCEA to select the preferred solution to address the Town's water storage needs and supply deficiencies in the Town's Eastern Pressure Zones. The preferred alternatives to this MCEA is the construction of new water treatment plant in the Eastern pressure zones with an additional 5,000m³ storage.

3.5 Infrastructure Leak Index


The Infrastructure Leakage Index (ILI) is a performance indicator of a system's water loss. ILI was developed by the International Water Association. The ILI is the ratio of current annual real losses to unavoidable annual real losses. It is derived from the structural and operational characteristics of the distribution system and is considered by the water industry as a better indicator of a system's condition.

The ILI calculation considers the length of service connections, the operating pressures, the length of the system and the number of users on the system.

There are four technical performance categories utilized for ILI values by the International Water Association Water Loss Task Force:

ILI 1 to 2	EXCELLENT	Further loss reduction may be uneconomical unless there are shortages.
ILI 2 to 4	GOOD	Potential for marked improvements, consider pressure management, better active leakage control practices and improved network maintenance.
ILI 4 to 8	POOR	Poor leakage record, tolerable only if water is plentiful and cheap, analyze level and nature of leakage and intensify leakage reduction efforts.
ILI >8	VERY BAD	Very inefficient use of resources; leakage reduction programs imperative and high priority.

Graph 3.4 below illustrates the ILI values for the Town from 2015 - 2024



The Town falls within the 'Good' range for managing non-revenue water or real losses. However, this category also identifies room for improvement and continual monitoring to further reduce the losses.

In 2024, the Town utilized some new technology to find leaks in the transmission trunk main. Xylem's Smart Ball™ was introduced in the drinking water system at the Thornbury Reservoir and ran through to Arrowhead Booster Station. The Smart Ball™ detected four (4) medium leaks and two (2) anomalies in the main. Staff will be repairing the leaks in 2025.

Table 3.4 Summary of Water Produced, Consumed and Lost

Year	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024
Water Produced (TBM) (ML)	1452.9	1618.2	1541.0	1585.3	1793.4	1899.8	2033.7	2004.1	2161.7	1991.8
Imported Water (ML)	222.9	190.0	171.0	212.7	185.0	198.4	198.7	199.6	194.8	195.8
Exported Water (ML)	54.8	24.0	25.9	31.5	32.9	35.5	42.9	40.3	50.5	44.0
Total Water Available (ML)	1621.0	1784.2	1686.2	1766.5	1945.5	2062.7	2189.4	2163.5	2306	2144
Billed Authorized Consumption (ML)	1054.3	1124.3	1057.0	1164.6	1335.6	1281.7	1258.2	1292.0	1289.2	1308.4
Unbilled Authorized Consumption (ML)	208.3	202.1	288.5	202.6	194.9	218.7	331.4	323.7	459	198.4
Apparent Losses* (ML)	101.1	101.5	102.2	102.4	102.9	103.2	103.4	103.4	103.8	103.4
Real Losses** (ML)	257.3	356.3	238.4	296.9	312.1	562.4	599.8	547.8	557.8	533.3
Real Water Loss (%)	15.9%	20.0%	14.1%	16.8%	16.0%	27.26%	27.39%	25.32%	24.19%	24.88
Total Water Loss (%)	22.1%	25.7%	20.2%	22.6%	21.3%	32.26%	32.11%	30.10%	28.68%	29.70

* Apparent Losses includes unauthorized consumption, customer metering inaccuracies and systematic data handling errors.

** Real Losses includes the total volume of water that cannot be accounted for.

The total percentage of water loss for 2024 was 29.70%. This was slightly higher than 2023. The Town is currently undertaking a leak detection program to identify and repair leaks to reduce the water loss. In addition, the Town has started a program to install flow meters on the watermain entering large developments on private lands. A mass balance with the individual residential meters will assist in identifying leaks on private lands.

In 2024, Staff repaired 2 watermain breaks and 13 service connection leaks. Both watermain breaks were in the Tyrolean Village area, and in both cases, the saddles had failed.

Staff continue to search for leaks, and evidence of water theft. Water theft has been found in new developments, with Construction Companies illegally operating curbstops, utilizing unmetered connections for water during construction, leaving curbstops running during winter months to prevent freezing and establishing stations to facilitate water theft.

In the fall of 2024, the Town partnered with Xylene to perform an inline leak inspection with the Smartball platform. The tool listens for leaks and air pockets using acoustic technology from inside the watermain. The Smartball inspected the trunk main from the Thornbury Reservoir on Grey Street to Arrowhead Road. The Smartball identified four (4) leaks and three (3) acoustic anomalies. Through some additional field work, one of the anomalies was determined to be a service leak. The leaks will be addressed in 2025.

The 2025 Approved Budget includes an additional staff member, focusing on leak detection in the water distribution system and Inflow and infiltration of the sanitary collection system.

4.0 Thornbury Wastewater Capacity Assessment

4.1 Thornbury WWTP Capacity

The Thornbury WWTP utilizes the activated sludge process, a variation of extended aeration, aerated grit removal, phosphorus removal by alum addition, secondary clarification, and disinfection by ultraviolet irradiation to treat wastewater. Treated effluent is discharged to the Beaver River via a gravity outfall. The Thornbury WWTP ADF capacity is 3,580 m³/day. The rated PDF capacity is 7,196 m³/day.

4.2 Inflow Rates

Table 4.1 summarizes the ADF and PDF that occurred over the period from 2015 to 2024.

Table 4.1 Thornbury WWTP Historical Flows

Year	# of Units	ADF (m ³ /day)	ADF (m ³ /unit/day)	5 Year Rolling ADF (m ³ /unit/day)	PDF (m ³ /day)	PDF (m ³ /unit/day)	5 Year Rolling PDF (m ³ /unit/day)
2015	2,559	1,836	0.717	0.911	4,546	1.776	2.738
2016	2,626	2,332	0.888	0.870	10,580	4.023	2.903
2017	2,668	2,767	1.037	0.899	7,617	2.854	2.921
2018	2,743	2,660	0.970	0.885	7,656	2.791	2.871
2019	2,868	2,780	0.969	0.916	6,696	2.334	2.756
2020	2,945	3,123	1.060	0.985	8,397	2.851	2.971
2021	3,130	2,567	0.820	0.971	9,118	2.913	2.749
2022	3,274	2,430	0.742	0.912	6,928	2.116	2.601
2023	3,399	2,658	0.782	0.875	9,218	2.712	2.585
2024	3,416	2,412	0.706	0.822	7,482	2.190	2.557
		2024 5 Year Rolling ADF/Unit = 0.822m ³ /unit/day 2024 5 Year Rolling ADF = 2,638 m ³ /day			2024 5 Year Rolling PDF/Unit = 2.556 m ³ /unit/day 2024 5 Year Rolling PDF = 8,229 m ³ /day Peaking Factor = 3.12		

The Thornbury WWTP rated capacity is 3,580 m³/day. The above data shows that the ADFs over the past five-year period have remained relatively constant, although there have been increased connections to the Thornbury WWTP. The ADF per unit has remained relatively consistent, with minor fluctuations. The 2024 ADF per unit is 0.706 m³/day. The five-year rolling ADF is 2,638 m³/day.

The PDFs are influenced by wet weather events. The total rainfall for 2023 and 2024 was average for the Thornbury area. The PDFs remained in an acceptable range. The ADF per unit in 2024 was slightly lower than in 2023. The PDF per unit was lower in 2024 than previous year. The PDF is often influenced by heavy rain events. The five-year rolling average PDF per unit is 2.557 m³/day. The five-year rolling

average PDF exceeds the Thornbury WWTP's rated PDF capacity of 7,196 m³/day, as this plant is reaching its rated capacity. During heavy rain events, excess influent is diverted to the lagoon system.

The existing flow to the Thornbury WWTP is utilizing 74% of the available ADF built capacity based on the 2022 five year rolling average.

$$\text{5 Year ADF } 2,638 \text{ m}^3/\text{day} \times 100\% = 74\%$$

Built Capacity 3,580 m³/day

The Town has commenced with the construction of the Phase 1A Plant Expansion which is due to be completed in the second quarter of 2025. The Phase 1A expansion will increase the capacity to the facility to 5,330 m³/day. The engineering for Phase 1B will commence in 2025. The Phase 1B expansion will increase the capacity to 7,080 m³/day. In order to realize the additional capacity of the Phase 1A expansion, the new outfall extending into Georgian Bay at the northern termination point of Grey Street will need to be completed and fully operational.


Tables B16 and B17 in Appendix F show the ten highest PDFs for 2023 and 2024. General findings that can be drawn for the data are:

In 2024 the PDF of 7,482 m³ occurred on December 30, 2024. This was during a heavy rain event.

Six of the highest peak flow events in 2024 occurred in the April, following rainfall events and four occurred in December, following snow melts.

Inflow and Infiltration in the Thornbury WWTP sewer shed significantly influence the flows to the WWTP.

Graph 4.1 illustrates a comparison of the number of wastewater units, the ADF and the PDF from 2015 to 2024



4.3 Total Thornbury WWTP Capacity

4.3.1 Built & Design Capacity

As discussed in Section 4.1 the ADF built capacity of the Thornbury WWTP is 3,580 m³/day. Using the five-year rolling ADF per unit flow rate to determine the total number of units that can be serviced results in the following:

$$\text{Total Facility Built Capacity: } \frac{3,580 \text{ m}^3/\text{day}}{0.822 \text{ m}^3/\text{unit}/\text{day}} = 4,355 \text{ units}$$

As discussed in Section 4.1, the Town currently has an Environmental Compliance Approval (ECA) that allows for the ADF capacity of the Thornbury WWTP to increase to 5,330 m³/day upon completion of the Phase 1A expansion and the commissioning of the new effluent outfall. The Town is currently constructing Phase 1A expansion, with plans to initiate the design of Phase 1B in 2025. Phase 1B will increase the ADF to 7,080 m³/day when the work is completed. In consideration that the Town only has an ECA with an approved expansion of 5,330 m³/day, this capacity will be used to determine the capacity of the Thornbury WWTP. Using the historical five-year ADF per unit flow rate to determine the total number of units that can be serviced results in the following:

$$\text{Total Facility Design Capacity } \frac{5,330 \text{ m}^3/\text{day}}{0.822 \text{ m}^3/\text{unit}/\text{day}} = 6,484 \text{ units}$$

4.3.2 Thornbury WWTP Capacity Status

Graph 4.2 summarizes the 2024 capacity status. A breakdown of the Thornbury WWTP capacity status is included in Appendix D.

Table 4.2 2024 Thornbury WWTP Unit Status

Year End Report Category	Official Plan Capacity Status	Number of Units	Flow (m ³ /d)*
1. Connected	Allocated	3416	2,808
2. Can Connect	Allocated	287	236
3. Committed	Allocated	0	0
Sub-Total Allocated (1+2+3)		3,703	3,044
4. Not Fronting, Not Serviced	Not Recognized	984	809
5. Designated Lands – Active	Reserved	172	141
Sub-Total Reserved(4+5)		1,156	950
Total Allocated + Reserved (2+3+4+5)		1,443	1,186
6. Designated Lands – Other	Not recognized	1,931	1,587
7. Designated Lands – No Proposal	Not recognized	3,006	2,471
Sub-Total Not Recognized (6+7)		4,937	4,058
Grand Total (1+2+3+4+5+6+7)		9796	8,052

*number of units multiplied by the 5-year rolling average ADF identified in Table 4.1

The “MECP Guideline for Year End Reporting” has been modified through discussions between the Town, Grey County and the MECP. The purpose of the modified method is to optimize the use of the Thornbury WWTP built capacity prior to commencing construction of additional capacity. The capacity calculation described below will outline the methodology used to calculate the uncommitted capacity available for Thornbury WWTP reservation.

4.3.3 Allocated and Reserve Capacity

For the purposes of calculating Committed Flows for the Thornbury WWTP only, the following definitions will be used:

Connected Servicing Capacity = Built Capacity – ADF

Built Capacity = 3,580 m³/day (Section 4.1)

Connected Flows = 2,808 m³/day (Table 4.1)

Therefore:

Allocated Servicing Capacity = 3,580 – 2,808 = 772 m³/day

Units available for allocation is $\frac{772 \text{ m}^3/\text{day}}{0.822 \text{ m}^3/\text{unit}/\text{day}} = 939 \text{ units}$

Allocated Servicing Capacity = Built Capacity – ADF – Allocated Flows

Built Capacity = 3,580 m³/day (Section 4.1)

Connected Flows = 2,808 m³/day (Table 4.1)

Allocated Flows = 236 m³/day (Can Connect + Committed Table 4.2)

Therefore:

Allocated Servicing Capacity = 3,580 – 2,808 – 236 (Committed Flows) = 536 m³/day

Units available for allocation is $\frac{536 \text{ m}^3/\text{day}}{0.822 \text{ m}^3/\text{unit}/\text{day}} = 652 \text{ units}$

Reserved Servicing Capacity

The Reserved Servicing Capacity is determined as follows:

Design Capacity = 5,330 m³/day (Section 4.1)

Connected Flows = 2,808 m³/day (Table 4.2)

Reserved Flows = 377 m³/day (Can Connect + Designated Lands Active Table 4.2)


Therefore:

Reserved Servicing Capacity = 5,330 – 2,808 – 377 = 2,145 m³/day

Units Available for reservation is $\frac{2,145 \text{ m}^3/\text{day}}{0.822 \text{ m}^3/\text{unit}/\text{day}} = 2,609 \text{ units}$

4.3.4 Flow & Unit Summary


Graph 4.2 below summarizes the Thornbury WWTP flows and units.



4.4 Flow Projections and Estimated Expansion Timeline

Graph 4.3 below provides a projection of the Thornbury WWTP connected, allocated and reserved units. The Thornbury WWTP is currently at 74% of capacity.

Graph 4.3 Thornbury Wastewater Treatment Plant Projections



4.4.1 Phasing of WWTP Expansion

The Phase 4 ESR from the Comprehensive EA identified that the first phase of the works to expand the Thornbury WWTP facility would provide an additional average day capacity of approximately 3,500 m³/day for a total average day capacity of 7,080 m³/day. Further to that report Stantec Consulting Ltd. prepared a 90% Design Report which identified that Phase 1 will be split into two (2) sub-phases with Phase 1A having an ADF capacity of 5,330 m³/day. Phase 1B will expand Thornbury WWTP ADF capacity to 7,080 m³/day and a PDF capacity of 16,187 m³/day.

In 2017, the Town completed an Addendum to the 2006 Environmental Assessment for the Thornbury Wastewater treatment plant. This Addendum looked at what had changed between 2006, when the initial EA was completed, and 2017. Upon completion of the EA, the Town applied for and acquired an ECA for the construction of Phase 1A of the Thornbury WWTP upgrades to enable the expansion when inflow reaches 80% of built capacity. The final design of the Phase 1A commenced in 2021, construction started in the second quarter of 2023 and to be completed by the second quarter of 2025.

The PDF into the plant exceeded the design PDF once in 2024. The collection system for this plant has significant inflow and infiltration (I&I) issues. The I&I issues have created large fluctuations in the ADF received by the plant impacting the total number of equivalent units that can be connected to the Plant. The Town initiated a Wastewater Master Plan, with a comprehensive flow monitoring program in 2023. It is anticipated that the Master Plan will be completed in early 2025. Additional flow monitoring has been added on the Master Plan project to help pinpoint areas of high I&I.

4.5 Wastewater Pumping Stations

4.5.1 Firm Capacity of Pumping Stations

The Thornbury Collection System has multiple Wastewater Pumping Stations. Each Pumping Station's capacity is listed below.

Camperdown Service Area

- Delphi Point WWPS firm pumping capacity is 53 L/s
- Lake Shore WWPS firm pumping capacity is 82 L/s
- Shore Acres WWPS firm pumping capacity is 10 L/s

Thornbury Service Area

- Moore Crescent WWPS has a firm pumping capacity of 13 L/s
- Peel Street WWPS has a firm pumping capacity of 38 L/s, station upgraded in 2023/2024.
- Elgin Street WWPS has a firm pumping capacity of 9 L/s
- The Mill Street Main WWPS has a firm pumping capacity is 160 L/s, however, the associated forcemain that conveys wastewater flow to the Thornbury WWTP has a capacity of 141 L/s, therefore, the rated capacity of Mill Street Main WWPS is 141 L/s

Lora Bay Service Area

- Sunset WWPS has a firm pumping capacity of 73 L/s

Cole Engineering Group completed a Needs Study of the sanitary system. This study identified the following:

Pumping Station	Dry Weather Flow Criteria Existing and future Conditions	Wet Weather flow Criteria – Existing and Future Conditions			
		2 Year Event	5 Year Event	25 Year Event	100-year Event
Delphi	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions
Elgin	Criteria met for existing and future conditions	Criteria not met for existing and future conditions	Criteria not met for existing and future conditions	Criteria not met for existing and future conditions	Criteria not met for existing and future conditions
Lakeshore	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions
Mill Street	Criteria met for existing and future conditions	Criteria not met under existing and future conditions	Criteria not met under existing and future conditions	Criteria not met under existing and future conditions	Criteria not met under existing and future conditions
Moore	Criteria met for existing and future conditions	Criteria partially met under existing and future conditions	Criteria partially met under existing and future conditions	Criteria partially met under existing and future conditions	Criteria partially met under existing and future conditions
Peel*	Criteria met for existing and future conditions	Criteria partially met under existing and future conditions	Criteria partially met under existing and future conditions	Criteria partially met under existing and future conditions	Criteria partially met under existing and future conditions
Shore Acres	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions
Sunset	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions

*Peel Sewage Pumping Station has been upgraded to meet the existing and future conditions

- The Delphi, Lakeshore, Shore Acres and Sunset pumping stations all have adequate capacity to The Town's level of service requirements under future conditions. Therefore, no additional capacity will be required at these stations.
- The Elgin pumping station was determined to not meet level of service requirements under wet weather flow conditions. The station capacity is exceeded, and a high-level alarm is predicted to

occur as a result of the 5-year, 25 year and 100-year storm events during the existing conditions. It is unlikely that the pumping station will overflow to the natural environment as a result of a 100-year event as the overflow invert is 5.3 meters above the wet well invert and the peak wet well level in a 100-year storm is predicted to reach 3.8 meters.

- The Town has commenced with upgrades to the Mill Street pumping station and replacement of the Bay Street sanitary collection system. This construction will result in lowering the level of the sanitary collection system, and eliminating the need for the Elgin pumping station. This station will be removed in 2026.
- The Mill Street pumping station was determined to not to meet level of service requirements under all wet weather flow conditions. Under existing and future wet weather flow conditions, the firm capacity is not sufficient to pump the 5-year incoming peak flows. There is also growth planned in the Mill Street pumping station service area. Additional capacity will be required at this station.
 - The Town has commenced with the final design of the required upgrades and additional forcemain from the station to the plant. Construction is anticipated to be completed in 2026.
- The Moore Street pumping station partially met level of service requirements as the peak flow entering the station. No growth has been identified for this service area, and an upgrade to the station is not required.
- The Peel Street pumping station has been upgraded to meet the demands of the existing and future conditions.
- The existing sanitary sewers on Victoria Street north of Huron Street, on Bay Street east of Mill Street, on Elgin Street south of King Street, on Arthur Street south of Peel and upstream of the Lakeshore PS, on Grey Road 40 upstream of the Shore acres PS and on High Bluff Lane did not meet the wet weather criteria for the 5-year storm under future conditions.
- Two sanitary sewers in Lora Bay on High Bluff Lane were identified that did not meet the criteria for the 5-year design storm event, however, the issue was not confirmed with the flow monitoring conducted in 2024 through the Master Plan.

The Town tendered the design for the Mill Street PS upgrades and an additional forcemain to the Thornbury WWTP in Q4 of 2022.

4.6 Peak Day Flow Observations

The Thornbury WWTP has an approved ADF capacity of 3,580 m³/day and a peak day flow (PDF) capacity of 7,196 m³/day. The Mill Street and Lakeshore WWPSs in Thornbury convey all sanitary sewage to the Thornbury WWTP.

Peak Daily Flows typically occur with a significant weather-related event such as excessive rainfall or run off from melting snow due to unusually high temperatures. These events typically cause very high flows for a short duration (usually less than one to two days). The Thornbury WWTP has significant hydraulic capacity in tankage which enables the facility to handle excess flows however the WWPSs are limited to capacities of pumps, forcemains and wet wells and as such need to transfer instantaneous flows.

The design PDF was exceeded once in 2024 on December 30th, with a peak flow of 7,482m³.

4.6.1 Wastewater Inflow & Infiltration Study (2014)

In 2014 an Inflow and Infiltration (I&I) Study Report was received from Cole Engineering which includes a number of recommendations to address I&I issues identified throughout the course of the study. The Town is acting on a number of the recommendations including the replacement of sanitary sewer in the Elma Street, Alice Street, Louisa Street and Victoria Street area as it is identified as a point in the Thornbury Collection System that reacts almost instantly to weather related events. The Town has also completed a Calibrated Sanitary Model for both the Thornbury and the Craigleith collection systems. This model will assist with planning of future flows.

In order to determine yearly PDF information at Wastewater Pumping Stations not outfitted with flow meters, Staff utilize pump hours to calculate flow rates. Staff will be recommending, during the budget process, that all pump stations include the addition of flow meters to accurately determine flow rates.

The Town commenced Wastewater Collection System Master Plan Environmental Assessment (MPEA) in 2022. The MPEA is reviewing and building on past studies plus incorporating current growth projections to determine the wastewater collection network to build out of the Official Plan. This study builds upon the Needs Assessment completed in 2019. The MPEA is anticipated to be completed in the second quarter of 2025. The work includes 12 months of flow data to calibrate the wastewater model.

5.0 Craigleith Wastewater Capacity Assessment

5.1 Craigleith WWTP Capacity

The Craigleith WWTP's Built ADF treatment capacity is 8,133 m³/day and the PDF capacity is 19,640 m³/day. The Craigleith WWTP utilizes an extended aeration process, incorporates tertiary effluent filtration and includes comminution, aerated grit removal, phosphorus removal by alum addition, secondary clarification, 2 stage aerobic sludge digestion and effluent disinfection by ultraviolet irradiation. All raw WW is pumped to the WWTP from the Craigleith Main WWPS, and treated effluent is discharged into Georgian Bay via a staged diffuser.

The Craigleith WWTP is operating at 42% of the built capacity.

5.2 Inflow Rates

Table 5.1 summarizes the ADF and PDF recorded at the Craigleith WWTP over the period from 2015 to 2024.

Table 5.1 Craigleith WWTP Historical Flows

Year	# of Units	ADF (m ³ /day)	ADF (m ³ /unit/d)	5 Year Rolling ADF (m ³ /unit/d)	PDF (m ³ /day)	PDF (m ³ /unit/d)	5 Year Rolling PDF (m ³ /unit/d)
2015	4,591	2,865	0.624	0.655	6,529	1.422	1.823
2016	4,661	3,202	0.689	0.662	12,428	2.666	1.912
2017	4,793	3,377	0.705	0.679	8,956	1.868	1.993
2018	4,935	3,284	0.665	0.673	10,491	2.126	1.970

2019	5,050	3,440	0.681	0.673	8,931	1.768	2.107
2020	5,273	3,579	0.679	0.684	10,558	2.002	2.086
2021	5,443	3,376	0.620	0.670	14,461	2.657	2.084
2022	5,587	3,248	0.581	0.645	9,767	1.748	2.060
2023	5,672	3,619	0.638	0.640	8,892	1.568	1.949
2024	5,720	3,317	0.580	0.620	8,752	1.530	1.901
		2024 5-Year Rolling ADF/Unit = 0.620 m ³ /day 2024 5-Year Rolling ADF = 3,428 m ³ /day			2024 5-Year Rolling PDF/Unit = 1.901 m ³ /day 2024 5-Year Rolling PDF = 10,486 m ³ /day Peaking Factor = 3.01		


The above data shows that the ADFs over the five-year period fluctuate when wetter years are experienced. The year 2024 was a fairly dry year. The ADF was slightly lower than the previous year, and the PDF was significantly higher than the previous year. The 2024 ADF was 3,317 m³/day and the PDF was 8,752 m³/day. The five-year rolling ADF is 3,428 m³/day and the five-year rolling average PDF is 10,486 m³/day. Based on the 2024 five year rolling ADF of 3,428 m³/day, the Craigleith WWTP is operating at 42% of the built capacity.

The five-year rolling average PDF falls within the Craigleith WWTP's rated PDF capacity of 19,640 m³/day.

Tables C13 to C14 in Appendix G summarize the ten highest daily flows for 2023 and 2024. The occurrences of peak flows were reviewed for 2024 with the key findings as follows:

- In 2024 the highest flow occurred on December 30th, during a high precipitation event.
- Ten peak influent events occurred mostly in December and April, corresponding with warmer temperatures and snow melt.

Graph 5.1 Illustrates a comparison of the number of WW units, the ADF and the PDF from 2015 to 2024.



ADF Treatment Capacity is 8,133 m³/day and PDF Treatment Capacity is 19,640 m³/day.

5.3 Total Craigleith WWTP Capacity

5.3.1 Built Capacity

As discussed in Section 5.1, the average day capacity of the Craigleith WWTP is 8,133 m³/day. Using the historical five (5) year rolling ADF per unit flow rate to determine the total number of units that can be serviced results in the following:

$$\text{Total Built Capacity} = \frac{8,133 \text{ m}^3/\text{day}}{0.620 \text{ m}^3/\text{unit}/\text{day}} = 13,118 \text{ units}$$

Table 5.2 and Graph 5.2 summarize the 2024 connection status. A breakdown of connection status is included in Appendix D.

5.3.2 Craigleith WWTP Capacity Status

Table 5.2 summarizes the 2024 capacity status. A breakdown of the Craigleith WWTP capacity status is included in Appendix D.

Table 5.2 2024 Craigleith WWTP Unit Status

Year End Report Category	Official Plan Capacity Status	Number of Units	Flow (m ³ /d) *
1. Connected	Allocated	5,720	3,546
2. Can Connect	Allocated	295	183
3. Committed	Allocated	0	0
Sub-Total Allocated(1+2+3)		6,015	3,729
4. Not Fronting, Not Serviced	Reserved	1,014	629
5. Designated Lands – Active	Reserved	1,557	965
Sub-Total Reserved (4+5)		2,571	1,594
Total Allocated + Reserved (2+3+4+5)		2,866	1,777
6. Designated Lands – Other	Not recognized	42	26
7. Designated Lands – No Proposal	Not recognized	5,468	3,390
Sub-Total Not Recognized (6+7)		5,510	3,416
Grand Total (1+2+3+4+5+6+7)		14,096	8,739

* number of units multiplied by the five-year rolling average ADF identified in Table 5.1

5.3.3 Allocated and Reserve Capacity

Using data from Tables 5.1 and 5.2, reserve capacity for the Craigleith WWTP is determined using the calculation below from Section 1.4.

Allocated Servicing Capacity = Built Capacity – Connected Flows – Allocated Flows

Built Capacity = 8,133 m³/day (Section 5.2.2)

Connected Flows = 3,546 m³/day (Table 5.2)

Allocated Flows = 1,777 m³/day (Can Connect [2] + Sub-Total Reserved [4+5] Table 5.2)

Therefore:


Reserved Servicing Capacity Flow = 8,133 – 3,546 – 1,777 = 2,810 m³/day

Units available for reservation =
$$\frac{\text{Reserved Servicing Capacity Flow (m}^3\text{/day)}}{\text{Flow per unit per day (m}^3\text{/unit/day)}}$$

$$\text{Units available for reservation} = \frac{2,810 \text{ m}^3/\text{day}}{0.620 \text{ m}^3/\text{unit}/\text{day}} = 4,532 \text{ units}$$

5.3.4 Flow & Unit Summary

Graph 5.2 below summarizes the Craigleith WWTP flows and units.



5.4 Wastewater Pumping Stations

5.4.1 Firm Capacity of Pumping Stations

The Craigleith Collection System has multiple Wastewater Pumping Stations. Each Pumping Station's capacity is listed below.

Craigleith Service Area

- Craigleith Main WWPS installed pumping capacity is 150 L/s (25,920 m³/day). Forcemain capacities are 227 L/s (19,639 m³/day). The Town commenced with the final design of the upgrades to the station in 2023, with construction anticipated in 2025.
- Summit Green WWPS firm pumping capacity is 4 L/s (346 m³/day)
- Margaret Drive WWPS firm pumping capacity is 60 L/s (5,184 m³/day)
- Alta WWPS firm pumping capacity is 6 L/s (518 m³/day)

In 2019 The Town undertook a Sanitary Needs Assessment. This work assessed the performance of the existing sanitary sewer system, including the sanitary sewers, pumping station and forcemains.

- The following areas were assessed:

Pumping Station	Dry Weather Flow Criteria Existing and future Conditions	Wet Weather flow Criteria – Existing and Future Conditions			
		2 Year Event	5 Year Event	25 Year Event	100-year Event
Alta	Criteria met for existing and future conditions, but not when s=planned service extension is included.	Criteria met for existing and future conditions, but not when s=planned service extension is included.	Criteria met for existing and future conditions, but not when s=planned service extension is included.	Criteria met for existing and future conditions, but not when s=planned service extension is included.	Criteria met for existing and future conditions, but not when s=planned service extension is included.
Craigleith	Criteria met for existing, not met for future conditions	Criteria not met for existing and future conditions	Criteria not met for existing and future conditions	Criteria partially met for existing and future conditions	Criteria partially met for existing and future conditions
Margaret	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions
Summit Green	Criteria met for existing and future conditions	Criteria partially met under existing and future conditions	Criteria partially met under existing and future conditions	Criteria met for existing and future conditions	Criteria met for existing and future conditions

- The Alta and Margaret PSs have adequate capacity to the Town’s level of service requirements under future conditions. However, the Alta PS does not have adequate capacity to accommodate additional flow from the Town’s planned service extensions. Additional capacity will be required at the Alta PS.
- At the Summit Green PS, the criteria are partially met under existing and future conditions for a 2-year and 5-year design storm event. Although the firm capacity is adequate to meet future needs, the peak wet well level exceeds the high-level alarm for these storm events. Modifications to the pump settings will be required. This station does not require an upgrade.
- The Craigleith PS, the criteria is not met for future dry weather conditions and for both existing and future wet weather conditions.
 - The final design of the required upgrades to the Craigleith Main lift station commenced in 2024. Construction is anticipated to be completed in 2026.
- Sanitary sewers located upstream of the Craigleith PS were also identified as not meeting the required level of service under existing and future conditions. Under a 25-year and 100-year design storms, the sanitary sewers on Grey Road 19 between Monterra Road and Kandahar Lane do not meet the criteria under future conditions.
- In 2021, the Town undertook an optimization program on the Craigleith WWPS The optimization program looked at the needed upgrades to the station, as well as energy efficiencies. The Town tendered the design of the upgrades for the station in Q4 of 2022.

In 2023, the Town proceeded with the Long Point Road Municipal Class Environmental Assessment (MCEA). This work was to determine the preferred solution for the 300 mm Jumper sewer between Grey 21 and Timmons Street. The preferred solution is the construction of a gravity sewer on Long Point Road and a lift station at the Craigleith WWTP. Also considered through this MCEA process was the preferred solution for the Town's Septic Receiving Station. The station will be relocated to the Craigleith WWTP. The preliminary design for the lift station and the septic receiving station was completed in 2024. The Town intends to proceed with the final design of the lift station, septic receiving station and gravity main in 2025.

5.4.2 Craigleith Main Wastewater Pumping Station

The Craigleith Main WWPS as noted in Section 5.4.1 has an installed capacity of 300 L/s or 25,920 m³/day and a firm capacity of 150 L/s or 12,960 m³/day. Using the 5-year historical per unit PDF of 1.901 m³/unit/day to determine units that can be serviced results in the following:

$$\text{Total Built Capacity} = \frac{\text{Installed pumping capacity (m}^3\text{/day)}}{\text{5 year historical per unit PDF (m}^3\text{/day/unit)}}$$


$$\text{Total Built Capacity} = \frac{25,920 \text{ m}^3\text{/day}}{1.901 \text{ m}^3\text{/day/unit}} = 13,635 \text{ units}$$

There are currently 8,586 units allocated or reserved. The Craigleith Main WWPS is over allocated by 1,936 units with the largest pumping unit out of service (firm capacity). With both pumps in service the built capacity is able to accommodate 13,299 units and thus there is surplus capacity 4,713 units. The risk is that there will be one pump out of service during a large flow event. Therefore, a review of the historical and projected flows is warranted.

Graph 5.3 below outlines both historical and projected flows from 2013-2027. Historical information from 2013-2023 is based on actual recorded flows, while 2024-2027 are projected based on a five-year rolling historical average. The long-term trending illustrates a reduction in PDF prior to 2016. The 2016 PDF indicates a sharp increase and can be attributed to significant wet weather events. The PDF for 2018 was slightly higher than 2017, however dropped off again in 2019, however another sharp increase in 2021, with a particularly heavy rain event on September 21, 2021. An increase in the capacity of the pumping station is required and replacement of infrastructure that has reached the end of its useful life. The Town commenced with the Engineering for the upgrades to the station in 2023. Construction is anticipated to commence in 2025.

The Town commenced Wastewater Collection System Master Plan Environmental Assessment (MPEA) in 2022. The MPEA is reviewing and building on past studies plus incorporating current growth projections to determine the wastewater collection network to build out of the Official Plan. This study builds upon the Needs Assessment completed in 2019. The MPEA is anticipated to be completed in the second quarter of 2025. The work includes 12 months of flow data, including a flow analysis of the flows from Short Term Accommodations (STAs) to ensure we are using the best available information when determining the impact from STAs.

Graph 5.3 Craigleith WWPS Historical and Projected Flows 2013-2027



Note 1: Installed capacity is 25,920 m³/day

Note 2: Firm capacity is 12,960 m³/day

Note 3: Projected PDF is estimated by calculating the rolling average of the five-year rolling actual historical PDF

5.5 Peak Day Flow Observations

The Craigleith WWTP has an approved ADF capacity of 8,133 m³/day and PDF of 19,650 m³/day. The Craigleith Main WWPS conveys all sanitary sewage to the Craigleith WWTP.

Peak Daily Flows typically occur with a significant weather-related event such as excessive rainfall or run off from melting snow due to unusually high temperatures. These events typically cause very high flows for a short duration (usually less than one to two days). The Craigleith WWTP has significant hydraulic capacity in tankage which enables the facility to handle excess flows however the WWPSs are limited to capacities of pumps, forcemains and wet wells and as such need to transfer instantaneous flows.

The peak daily flow for the Craigleith WWTP in 2024 occurred on December 30th. The flow was 8,752 m³/day, and this is lower than the peak daily flow in 2023, which was 8,892 m³/day. The peak daily flow occurred during the peak time for the ski hills, and the temperatures indicated a snow melt. The flow was much less than Craigleith WWTP design PDF of 19,650 m³/day. There was adequate capacity at the WWTP to deal with peak flow.

5.5.1 Wastewater Inflow & Infiltration Study (2014)

In 2014 an Inflow and Infiltration (I&I) Study Report was received from Cole Engineering which put forward a number of recommendations to address I&I issues identified throughout the course of the study. The Town has also developed a calibrated sanitary model with Cole Engineering. The model will be a valuable tool for planning.

In 2018, the Town initiated the first year of a seven-year sanitary sewer condition assessment program. The program includes CCTV inspection and condition assessment in accordance with the National Association of Sewer Services Companies (NASSCO's) Pipeline Assessment and Certification Program.

6.0 Conclusions and Recommendations

The following table summarizes the capacity status of the water supply and wastewater treatment facilities based on units.

Table 6.1 Summary of Capacity Status for Key Infrastructure (Units) for 2024

Infrastructure	A Total Plant Capacity	B Total units Allocated	C Total units Reserved	D Total Allocated + Reserved (B+C)	E Units Available (A-D)
Water Supply (The Blue Mountains WTP + Collingwood Supply)	16,357	10,907	2,548	13,455	2,902
Thornbury WWTP (Built Capacity) *	4,355	3,703	203	3,906	449
Thornbury WWTP (Design Capacity)	6,484	3,703	203	3,906	2,578
Craighleith WWTP	13,118	6,015	2,571	8,586	4,532

The highlights of the Water Supply and WWTPs is provided below.

Water Supply

- ADD (5,948 m3/day) and the MDD (9,631 m3/day) the ADD and the MDD both decreased slightly from 2023 to 2024. The summer of 2023 was a hot dry summer, however, 2024 was a little cooler, consequently less water was used for irrigation.
- In 2024, the number of connected water units increased by 65 units to 10,230 units.
- Capacity is currently available for an additional 2,902 units and a system increase is not necessary, however the Town has initiated an Environmental Assessment to evaluate the long-term supply needs for the Town. It is anticipated that the study will be completed in 2025.
- This evaluation for 2024 includes the capacity required for the additional units proposed at Sites B, E & F.

Thornbury WWTP

- ADF (2,412 m³/day), decreased from 2023 and the PDF (7,482 m³/day) decreased from 2023.
- In 2024 the number of connected wastewater units increased by 17 units to 3,416 units.
- Thornbury WWTP is currently operating at 74% ADF built capacity based on five-year rolling average of recorded flow.
- High peak wastewater flows in Thornbury throughout 2024 can be attributed to snow melt and wet weather events during the first part of the year.
- A new ECA for the Thornbury WWTP was issued March 23, 2023. The Proposed Construction Clause expires in March 2028. This ECA includes provisions for the Phase 1A expansion.
- Construction of the proposed works is anticipated to be completed in 2025.
- The construction of a new effluent outfall to Georgian Bay commenced in 2025.

Craigleith WWTP

- ADF (3,317 m³/day) decreased slightly from 2023, and PDF (8,752 m³/day) decreased significantly from 2023.
- In 2024 the number of connected wastewater units increased by 48 units to 5,720 units.
- There are 7,398 additional units which can be physically connected to the Craigleith WWTP.
- This evaluation includes the capacity required for the additional units proposed at Sites B, E & F.
- High peak wastewater flows in Craigleith over the past few years have generally corresponded with peak ski season, particularly Christmas and March Break, however in 2024, the peak flows occurred mostly during heavy rain events and snow melt.

Appendix A – Figure 1 – Development Staging Process













Figure 1: Development Staging Process





Water Class	
	Not Assigned
	1 Connected
	2 Can Connect
	4 Existing Not Fronting
	5 Reserved -Planning Approvals
	6 Designated (With Proposal)
	7 Designated (No Proposal)
	8 Future Development

Town of The Blue Mountains - 2024 Year End Report









WATER SUPPLY AND DISTRIBUTION

Unit Counts and Connections By Property (Water Service Only)





Sewer Class

- | | | | |
|---|-------------------------|---|--------------------------------|
|  | Not Assigned |  | 5 Reserved -Planning Approvals |
|  | 1 Connected |  | 6 Designated (With Proposal) |
|  | 2 Can Connect |  | 7 Designated (No Proposal) |
|  | 4 Existing Not Fronting |  | 8 Future Development |


Town of The Blue Mountains - 2024 Year End Report

SANITARY SEWER COLLECTION

Thornbury Waste Water Treatment Plant




0 500 1,000 2,000 Meters



DETAIL: Castle Glen / Osler



DETAIL: Blue Mountain Village




- Sewer Class**
- Not Assigned
 - 1 Connected
 - 2 Can Connect
 - 4 Existing Not Fronting
 - 5 Reserved -Planning Approvals
 - 6 Designated (With Proposal)
 - 7 Designated (No Proposal)
 - 8 Future Development


Town of The Blue Mountains - 2024 Year End Report

SANITARY SEWER COLLECTION

Craighleith Waste Water Treatment Plant



Appendix C – Water Pressure Zone Boundary Map



Appendix D – 2024 Capacity Chart

2024 Thornbury Waste Water Treatment Plant																	Print Date	3/5/2025	12:59:55 PM
	Service Area	Connected	Connected (Eq. Units)	TOTAL CONNECTED UNITS	Can Connect	CanConnectEU	TOTAL ALLOCATED UNITS	Reserved	TOTAL ALLOCATED + RESERVED UNITS	Existing Not Fronting	Existing Not Fronting (Eq. Units)	Designated (With Proposal)	Designated (No Proposal)	Future Development (DD Lands)	TOTAL FUTURE CONNECTIONS	GRAND TOTAL			
0	RURAL	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
2	Camperdown	608	113	721	149	2	872	34	906	163	56	322	561	98	1200	2106			
5	Lora Bay	667	22	689	83	0	772	35	807	242	4	96	802	271	1415	2222			
6	Clarksburg	23	2	25	1	0	26	0	26	346	71	0	840	0	1257	1283			
8	Thornbury (east)	253	88	341	8	4	353	42	395	19	6	127	124	0	276	671			
9	Thornbury (west)	1233	407	1640	25	15	1680	61	1741	77	0	235	679	782	1773	3514			
Total		2784	632	3416	266	21	3703	172	3875	847	137	780	3006	1151	5921	9796			
2024 Craigleith Waste Water Treatment Plant																			
	Service Area	Connected	Connected (Eq. Units)	TOTAL CONNECTED UNITS	Can Connect	CanConnectEU	TOTAL ALLOCATED UNITS	Reserved	Existing Not Fronting	Existing Not Fronting (Eq. Units)	TOTAL ALLOCATED + RESERVED UNITS	Designated (With Proposal)	Designated (No Proposal)	Future Development (DD Lands)	TOTAL FUTURE CONNECTIONS	GRAND TOTAL			
0	RURAL	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
1	Craigleith	3424	2296	5720	257	38	6015	1557	472	174	8218	42	1622	2003	3667	11885			
3	Castle Glen	0	0	0	0	0	0	0	86	1	87	0	1843	0	1843	1930			
4	Swiss Meadows	0	0	0	0	0	0	0	129	2	131	0	0	0	0	131			
7	Osler	0	0	0	0	0	0	0	0	150	150	0	0	0	0	150			
Total		3424	2296	5720	257	38	6015	1557	687	327	8586	42	3465	2003	5510	14096			
2024 Town of The Blue Mountains Water Supply																			
	Service Area	Connected	Connected (Eq. Units)	TOTAL CONNECTED UNITS	Can Connect	Can ConnectEU	TOTAL ALLOCATED UNITS	Reserved	Existing Not Fronting	Existing Not Fronting (Eq. Units)	TOTAL ALLOCATED + RESERVED UNITS	Designated (With Proposal)	Designated (No Proposal)	Future Development (DD Lands)	TOTAL FUTURE CONNECTIONS	GRAND TOTAL			
0	RURAL	6	0	6	4	0	10	0	0	0	10	0	0	0	0	10			
1	Craigleith	3858	2453	6311	269	57	6637	1557	25	0	8219	42	1622	2003	3667	11886			
2	Camperdown	737	136	873	162	4	1039	34	16	37	1126	322	561	98	981	2107			
3	Castle Glen	0	0	0	0	0	0	0	86	1	87	0	1843	0	1843	1930			
4	Swiss Meadows	114	2	116	13	0	129	0	2	0	131	0	0	0	0	131			
5	Lora Bay	775	22	797	99	0	896	35	118	4	1053	96	802	271	1169	2222			
6	Clarksburg	82	6	88	14	0	102	0	274	67	443	0	840	0	840	1283			
7	Osler	0	0	0	0	0	0	0	0	150	150	0	0	0	0	150			
8	Thornbury (east)	266	90	356	9	6	371	42	5	0	418	127	124	0	251	669			
9	Thornbury (west)	1276	407	1683	25	15	1723	61	34	0	1818	235	679	782	1696	3514			
Total		7114	3116	10230	595	82	10907	1729	560	259	13455	822	6471	3154	10447	23902			

Appendix E – WTP 10 Water Demands

Thornbury Water Treatment Plant

Tables A16 & A17: Top 10 Highest Water Demands, 2023 – 2024

Table A16 – 2023

Rank	Month	Day	Flow (m ³)	Units	m ³ /d/unit
1	September	3	10,362	10,165	1.02
2	July	8	9,885	10,165	0.97
3	August	5	9,390	10,165	0.92
4	June	3	9,342	10,165	0.92
5	July	4	9,173	10,165	0.92
6	July	18	9,087	10,165	0.89
7	June	21	8,952	10,165	0.88
8	June	2	8,942	10,165	0.88
9	September	1	8870	10,165	0.87
10	July	19	8824	10,165	0.87

Table A17 – 2024

Rank	Month	Day	Flow (m ³)	Units	m ³ /d/unit
1	August	4	9631	10,230	0.94
2	August	27	9529	10,230	0.93
3	July	29	9435	10,230	0.92
4	July	27	9,316	10,230	0.91
5	August	3	9,286	10,230	0.91
6	July	1	8,933	10,230	0.87
7	July	7	8,903	10,230	0.87
8	August	2	8,887	10,230	0.87
9	July	28	8,885	10,230	0.87
10	August	26	8,836	10,230	0.86

2023 Average 9,283 m³

2024 Average 9,164m³

	Peak Season (Christmas, Family Day & March Break)
	Summer Season
	Winter Season

Appendix F – Thornbury WWTP 2023 and 2024 Top 10 Peak Flows

Thornbury WWTP

Tables B16 and B17: Top 10 Highest Peak Flows, Thornbury WWTP 2023 – 2024

Table B16 – 2023

Rank	Month	Day	Flow (m ³)	Units	m ³ /d/unit
1	April	5	9,218	3,399	2.71
2	April	6	8,571	3,399	2.52
3	January	5	7,178	3,399	2.11
4	April	7	6,114	3,399	1.80
6	April	1	5,403	3,399	1.59
7	February	10	5,350	3,399	1.57
8	April	8	5,174	3,399	1.52
9	January	4	5,167	3,399	1.52

2023 Average 6,282 m³

2023 Average 5,761 m³

	Peak Season (Christmas, Family Day & March Break)
	Summer Season
	Winter Season

Table B17 – 2024

Rank	Month	Day	Flow (m ³)	Units	m ³ /d/unit
2	April	18	6376	3416	1.87
4	April	13	5704	3416	1.67
6	April	14	5587	3416	1.63
7	December	17	5551	3416	1.63
8	April	19	5480	3416	1.60
9	April	20	4957	3416	1.45
10	April	17	4892	3416	1.43

Appendix G – Craigleith WWTP – 2023 and 2024, Top 10 Peak Flows

Craigleith WWTP

Tables C16 C17: Top 10 Highest Peak Flows, Craigleith WWTP 2023 – 2024

Table C16 – 2023

Rank	Month	Day	Flow (m³)	Units	m³/d/unit
2	April	5	7,893	5,672	1.39
4	January	5	7,155	5,672	1.26
6	February	10	6,955	5,672	1.23
7	January	2	6,952	5,672	1.23
8	October	8	6,872	5,672	1.21
9	January	4	6,645	5,672	1.17

Table C17 – 2024

Rank	Month	Day	Flow (m³)	Units	m³/d/unit
2	July	10	7,757	5,720	1.36
4	April	13	7,034	5,720	1.23
6	April	14	6,396	5,720	1.12
7	April	12	6,374	5,720	1.11
8	January	27	6,313	5,720	1.10
9	April	18	6,250	5,720	1.09
10	January	26	6,143	5,720	1.07

2023 Average 7,225 m³

2024 Average 6,918 m³

	Peak Season (Christmas, Family Day & March Break)
	Summer Season
	Winter Season

Appendix H – Basis for Calculating Equivalent Units

APPENDIX "A"

TOWNSHIP OF COLLINGWOOD

CRIAGLEITH - CAMPERDOWN AREA SERVICES

WATER WORKS PROJECT NO. 3-0174

SEWAGE WORKS PROJECT NO. 7-0242

CUSTOMER INVENTORY REVIEW

Basis for Equivalent Units

<u>Facility</u>	<u>Units</u>
Dwelling - single family unit	1
Multiple Unit, Apartment, Condominium, Efficiency Unit - unit	1
Hotel, Motel (No cooking facilities) - 1 room	1/2
Lodge, Hostel, Dormitory accommodation (More than 4 beds/room)-4 beds	1
Restaurants, Licenced Lounges, Cocktail Bars -12 seats	1
Commercial, Professional Offices, Retail Outlets (Take out restaurant, variety store) up to 7,000 sq. ft.-building	2
Major Retail/Offices 7,000 sq. ft. and over - building	3
Gas Bar (no repair service)	1
Service Station	3
Storage/Private Garage with washroom facilities	1
Laundromat Commercial - 1 machine	1
Campground -4 sites	1

Residential unit attached to commercial building add
1 unit to commercial value.

Ainley and Associates Limited
Consulting Engineers and Planners
105 Hurontario Street
COLLINGWOOD, Ontario
L9Y 2L9

File No. 81170
February, 1982